

STORZ CONNECTION



Figure 1402



FEATURES & BENEFITS

- Threadless connections save time and eliminate connection errors
- Safety locks to secure connection
- Stainless steel screen protects the waterway from foreign debris
- Metal face seal on Storz body
- Rubber gaskets on cap

AVAILABLE CONFIGURATIONS

- 4" Storz x 4" FNPT
- 5" Storz x 4" FNPT
- 4" Storz x 4" FNPT with 30° elbow
- 5" Storz x 4" FNPT with 30° elbow

CAP OPTIONS

- 4" Storz Cap w/ chain
- 5" Storz Cap w/ chain

ACCESSORIES

- 4" Round Auto Sprinkler Fire Department Connection sign (NFP101601)

MATERIALS

- Body: Aluminum 6061
- Screen/Lock Lever/Components: SS 304
- O-Ring/Gasket: NBR

PART NUMBER	CONNECTION 1	CONNECTION 2	PATTERN
NFP140201	4" STORZ	4" FNPT	Straight
NFP140202	5" STORZ	4" FNPT	Straight
NFP140203	4" STORZ	4" FNPT	30° Elbow
NFP140204	5" STORZ	4" FNPT	30° Elbow
NFP140205	4" STORZ	—	Cap
NFP140206	5" STORZ	—	Cap

INSTALLATION

Before installation, ensure all pipe and connections are free of debris. Secure the Storz connection to the inlet pipe. Do not overtighten! Overtightening could damage the threads, causing leaks or malfunctions. When installing a cap, align the marked notches on both the connection and the cap (labeled A in figure 1), rotate clockwise until the safety latch locks into place and attach the chain to the connection. To remove cap, press down on the safety latch and rotate counter clockwise.

