



**Regular and thorough cleaning of your interceptor assures maximum operating efficiency.
Here's what you need to know:**

When to Clean Your Interceptor

It is time to clean your Rockford interceptor when you notice a gradual slowdown of the drainage at the fixtures that are draining into the unit. With normal use, you should be able to establish a cleaning cycle. Whether once a week, or once a month. A thorough and regular cleaning each time will assure maximum operating efficiency, and will extend the life of your interceptor.

Rockford does not recommend adding enzymes or other short-circuiting products to a grease interceptor.

How to Clean Your Interceptor

1. Remove all grates to gain full access to the internal parts of the separator.
2. Remove all parts, and clean. Pump out the entire unit, removing all oily waste and sediment that will accumulate on the bottom. **DO NOT DISPOSE OF INTO THE SEWER.**
3. Replace all parts. Call Rockford if your separator parts are in need of replacement. All parts are usually in stock.
4. Run enough water to the separator, to restore the trap seal.

