Single-zone Pump Relay

Submittal Information Revision A: May 15, 2008

Project Information

Job Name:

JOD Name.		
Location:	Part No. Ordered:	
Engineer:	Date Submitted:	
Contractor:	Submitted By:	
Manufacturer's Representative:	Approved By:	

Technical Data

✓ Description	Part Number	Α	В	С	Weight
Single-zone Pump Relay	A3010100	4.25"	5.25"	2.75"	2.30 lbs.

Installation

Connect the thermostat to the "T T" terminals on the switching relay. When the thermostat calls for heat, the relay is energized and power is given to the circulator. Refer to the Uponor Single-zone Pump Relay Instruction Sheet for additional information.

Standards	
N/A	
Codes	
N/A	
Listings	
N/A	

Related Applications

Radiant Heating and Cooling Systems

Contact Information

Uponor, Inc. 5925 148th Street West Apple Valley, MN 55124 USA Phone: (800) 321-4739 Fax: (952) 891-2008 www.uponor-usa.com Uponor Ltd. 655 Park Street Regina, SK S4N 5N1 CANADA Phone: (888) 994-7726 Fax: (800) 638-9517 www.uponor.ca

uponor