SSTIII STAINLESS STEEL TAPPING SLEEVE WITH STAINLESS STEEL FLANGE & REMOVEABLE BOLTS

SUBMITTAL INFORMATION



NOTE: Sleeve meets the requirements of MSS SP-60 and AWWA C223.

MATERIALS

FLANGE

304 Stainless Steel Flange per AWWA C228-08. ANSI class 125 and 150 drillings and recessed to accept tapping valve. GMAW welded to neck.

STAINLESS STEEL

Meets or exceeds ASTM A 240 type 304 UNS designated S30400.

OUTLET

Heavy gauge 304L Stainless Steel. Fused to shell by GMAW weld on the outside and GTAW weld on the inside.

SHELL

Heavy gauge Stainless Steel top half 304L back half 304.

SIDEBARS

Heavy gauge 304 Stainless Steel, GTAW welded to form permanent fusion with shell.

BOLTS

5/8"-11 UNC thread track head, type 304 stainless steel

per ASTM A 193.

NUTS

5/8" heavy hex, type 304 Stainless Steel per ASTM A 194. Nuts coated to prevent galling.

WASHERS

5/8" 304 Stainless Steel flat washers and 5/8" Plastic washer. The Plastic washer helps prevents galling between nut and stainless steel washer.

ARMORS

Heavy gauge 304 Stainless Steel.

GASKETS

NSF 61 certified virgin SBR rubber compounded for water and sewer service in accordance with ASTM D 2000. Specially designed grid pattern and tapered ends to assure seal around full circumference of pipe. Reinforced ring at outlet provides hydrodynamic seal. Other compounds available for petroleum or high temperature service, or other special applications.

WELDS

GMAW and GTAW weld processes. 308L Stainless Steel filler wire used as appropriate. Flange weld is GMAW type proprietary process. Tapping Sleeve is fully passivated for enhanced corrosion resistance.

PRESSURE

When properly installed, the Romac Style SST Tapping Sleeve can work at these pressures ratings:

PIPE SIZE	WORKING PRESSURE	TEST PRESSURE
4"-8"	250 psi	312 psi
10" - 24"	200 psi	300 psi
26" - 30"	150 nsi	187 nsi

SIZES & RANGES

SEE CATALOG.

This information is based on the best data available at the date printed above. Please check with Romac for any updates or changes.

