

#2 ECLIPSE POST HYDRANT SHALL BE SELF-DRAINING, NON-FREEZING, COMPRESSION TYPE WITH 2-3/16" MAIN VALVE OPENING. INLET CONNECTION SHALL BE (2" FIP, 2-1/2" FIP, 3" FIP, 2" MJ, 3" MJ OR 4" MJ). OUTLET SHALL BE (1-1/4", 1-1/2", 2" OR 2-1/2" IP OR NST). STANDARD DEPTH OF BURY IS 3'.

ALL WATER FLOW SHALL PASS THRU A 3-1/2" FBE COATED STEEL PIPE AND CAST IRON TOP STOCK WATERWAY.

ALL WORKING PARTS SHALL BE SERVICEABLE FROM ABOVE GROUND WITH NO DIGGING OR REPLACEMENT NEEDED.

HYDRANT SHALL BE SET IN 4 CUBIC FEET OF CRUSHED STONE TO ALLOW FOR PROPER DRAINAGE OF HYDRANT. RECOMMENDATION OF THE AWWA SHOULD BE FOLLOWED WHEN INSTALLING THE HYDRANT.

THE #2 ECLIPSE POST HYDRANT AS MANUFACTURED BY THE KUPFERLE FOUNDRY, ST. LOUIS MO. 63102 OR APPROVED EQUAL.

NOTES:

THE #2 HYDRANT

DATE

1-1/5"=1

05/11/17

INLET SHALL BE:

OUTLET SHALL BE:

#2 ECLIPSE POST HYDRANT TO BE INSTALLED AT THE FOLLOWING LOCATIONS:

ITEM	ITEM / DESCRIPTI□N	NOTES	
1	OPERATING SCREW	•	
2	TOP CAP		
3	SIDE CAP		
4	TOP STOCK		
5	3-1/2" FBE COATED STEEL PIPE		
6	DRAIN HOLE		
7	COUPLING		
8	INLET VALVE BODY		
9	UNDISTURBED EARTH	BY OTHERS	
10	VALVE BOX	BY DTHERS	
11	THRUST BLOCKS	BY OTHERS	
12	CRUSHED ROCK	BY OTHERS	
13	HYDRANT SHUT-OFF VALVE	BY OTHERS	

					INITIA
				DRAWN	SMS
				APPROVED	DCL
				MODIFIED	SMS
D/MM/YY	ISSUED FOR REFERENCE				
DATE	STATUS / REVISION	#2 ECLIPSE POST	HYDRANT		



2511 NORTH 9TH STREET ST. LOUIS, MO 63102 1-800-231-3990 FAX 314-231-2820 www.hydrants.com

SHEET 1 DF 1