

Seamless Pipe Nipples - Black & Galvanized

Standard Schedule 40, XH Schedule 80, Schedule 160, XXH



FIG. 320:
Standard
Black Sch. 40

FIG. 325:
Extra Heavy
Black Sch. 80

FIG. 326:
160
Black Sch. 160

FIG. 327:
XXH
Black

FIG. 330:
Standard
Galv. Sch. 40

FIG. 335:
Extra Heavy
Galv. Sch. 80

FIG. 333:
160
Galv. Sch. 160

FIG. 329:
XXH
Galvanized

Specifications


Dimensions: ASTM A733 (See table below for standard sizes)

Threads: NPT per ASME B1.20.1

Material: ASTM A106 Grade B Seamless Pipe

ASTM A333 Grade 6 Seamless Pipe (For Canada only)

Finish: ASTM A106 Nipples Phosphate Coated or Hot Dip Galvanized
ASTM A333 Nipples Phosphate Coated or Zinc Electroplated



Pipe Size	Pipe O.D.	Length Close	Pipe Nipple Lengths																		
			in	in	in	1 1/2	2	2 1/2	3	3 1/2	4	4 1/2	5	5 1/2	6	7	8	9	10	11	12
1/8	0.405	3/4				1 1/2	2	2 1/2	3	3 1/2	4	4 1/2	5	5 1/2	6	7	8	9	10	11	12
1/4	0.540	7/8				1 1/2	2	2 1/2	3	3 1/2	4	4 1/2	5	5 1/2	6	7	8	9	10	11	12
5/16	0.675	1				1 1/2	2	2 1/2	3	3 1/2	4	4 1/2	5	5 1/2	6	7	8	9	10	11	12
3/8	0.840	1 1/8				1 1/2	2	2 1/2	3	3 1/2	4	4 1/2	5	5 1/2	6	7	8	9	10	11	12
7/16	1.050	1 1/8				1 1/2	2	2 1/2	3	3 1/2	4	4 1/2	5	5 1/2	6	7	8	9	10	11	12
1/2	1.315	1 1/2				2	2 1/2	3	3 1/2	4	4 1/2	5	5 1/2	6	7	8	9	10	11	12	
5/8	1.660	1 5/8				2	2 1/2	3	3 1/2	4	4 1/2	5	5 1/2	6	7	8	9	10	11	12	
11/16	1.900	1 1/4				2	2 1/2	3	3 1/2	4	4 1/2	5	5 1/2	6	7	8	9	10	11	12	
3/4	2.375	2					2 1/2	3	3 1/2	4	4 1/2	5	5 1/2	6	7	8	9	10	11	12	
7/8	2.875	2 1/2						3	3 1/2	4	4 1/2	5	5 1/2	6	7	8	9	10	11	12	
1	3.500	2 5/8						3	3 1/2	4	4 1/2	5	5 1/2	6	7	8	9	10	11	12	
1 1/8	4.500	2 1/8								4	4 1/2	5	5 1/2	6	7	8	9	10	11	12	
1 1/4	5.563	3									4 1/2	5	5 1/2	6	7	8	9	10	11	12	
1 3/8	6.625	3 1/8									4 1/2	5	5 1/2	6	7	8	9	10	11	12	

Note: Other lengths available upon request.

8" Pipe Size available as POA - contact your Anvil Representative for details.

PROJECT INFORMATION															APPROVAL STAMP				
Project:															<input type="checkbox"/> Approved				
Address:															<input type="checkbox"/> Approved as noted				
Contractor:															<input type="checkbox"/> Not approved				
Engineer:															Remarks:				
Submittal Date:																			
Notes 1:																			
Notes 2:																			