



# ONE-LOK™ Series SLCE for PVC Pipe



## Features & Advantages:

1) The SIGMA ONE-LOK Series SLCE is a mechanical joint restraining gland that implements a series of individually activated wedges into the mechanical joint follower gland. When the wedge segment is engaged by the actuating bolt, the primary contact edges of each wedge segment lock onto the pipe wall. This action causes the primary contact edges to grip the pipe and effectively restrain all classifications of both AWWA C900/C905 and ASTM D2241 IPS size PVC pipe.


2) ONE-LOK SLCE's precision contoured wedges provide proper contact and support of the PVC pipe wall. Each wedge is manufactured with an elongated contour that evenly matches the outside circumference of each nominal diameter of PVC pipe.

3) ONE-LOK SLCE's wedge actuating bolt provides the installer with two visual torque indicators. The breakaway top and secondary shoulder stop ensure proper engagement of the wedge segment at the time of installation. Unlike other actuating bolts, the ONE-LOK SLCE is manufactured with a proprietary quality control system that ensures the breakaway tops will activate at the correct torque. The breakaway top is sized to match the same dimensions of the bolts and nuts used to assemble the mechanical joint fitting and follower gland, eliminating the need for special installation tools. Once engaged, the actuating bolt leaves a residual hex-head shank, allowing post-installation disassembly of the restrained joint, if necessary.

4) ONE-LOK SLCE also features a non-corrosive, two-piece ABS plastic spacer that is removed when using the product to restrain IPS sized pipes meeting ASTM D2241. The two-piece design of this spacer allows it to be removed without requiring disassembly of the product. When the ONE-LOK SLCE is used to restrain pipes meeting AWWA C900, the spacer is left intact on the actuating bolt.

5) ONE-LOK SLCE's unique wedge segment and actuating bolt design allows the two components to interface using a cam action principle, allowing the wedge segments to rock and increase their grip on the pipe wall as thrust on the assembled joint increases. This also allows improved resistance to subsidence, seismic forces, and other movement within the maximum deflection limitations of the mechanical joint under applicable AWWA standards.


SIGMA ONE-LOK SLCE's can be used on all pressure classes and thicknesses of PVC pipe.



ONE-LOK's unique **CAM ACTION** allows the restraining lugs to "rock" and grip the PVC pipe wall more securely as thrust force increases, and allows for subsidence, seismic or other forces after installation, up to the maximum allowed deflection.



# ONE-LOK™ Series SLCE for PVC Pipe







## Sample Specification:


Restraint for standard mechanical joint fittings shall be incorporated in the design of the follower gland and shall utilize multiple wedge segments that act against the pipe, increasing their resistance as the line pressure increases. The assembled joint shall maintain the maximum flexibility and deflection of all nominal pipe sizes after burial. Restraining gland, wedge segments, and actuating bolts shall be manufactured of high strength ductile iron conforming to the requirements of ASTM A536, Grade 65-45-12. Dimensions shall be compatible with standardized mechanical joints conforming to the requirements AWWA C111/ANSI A21.11 and AWWA C153/ANSI 21.53 through 24" (latest revision). Breakaway tops shall be incorporated in the design of the actuating bolts to visually ensure proper torque. The manufacturing of the actuating bolt must incorporate a quality control procedure that is deemed acceptable by the specifier and positively assures precise and consistent operating torque of the breakaway top. The mechanical joint restraining devices shall have a working pressure rating of 200psi (235psi for sizes 14-36") minimum and provide no less than a safety factor of 2:1. Restraint shall be FM approved in applicable sizes. Restraining device shall be SIGMA ONE-LOK™ or approved equal.

## Material:

- Gland body, brackets, wedge segments & actuating bolts ASTM A536 65-45-12 ductile iron.
- Restraining Rods & Nuts: High strength, low alloy steel meeting AWWA/ANSI C111/A21.11 with minimum 65,000 psi tensile strength and 45,000 psi yield strength.
- Side Clamping Bolts & Hex Nuts: ASTM A449 high strength steel.



SECTION B - B



SECTION A - A

## Dimensions in Inches, Weights in Pounds

Size	Item #	Weight	PVC Pipe DI OD	IPS Pipe OD	Dimensions								Bolts and Inserts		
					C	F	K2	T	P	P*	X	J	No	Size	Torque
3	SLCE3	6.21		3.50	4.76	3.60	7.18	0.60	9.42	8.50	0.750	6.14	2	7/8	45-55
4	SLCE4	6.78	4.80	4.50	5.92	4.90	7.92	0.60	10.22	9.30	0.875	7.50	2	7/8	50-60
6	SLCE6	10.28	6.90	6.63	8.01	7.00	10.00	0.60	12.87	11.95	0.875	9.50	3	7/8	50-60
8	SLCE8	14.48	9.05	8.63	10.17	9.15	12.18	0.75	14.37	13.45	0.875	11.75	4	7/8	50-60
10	SLCE10	21.40	11.10	10.75	12.22	11.20	14.60	0.85	16.68	15.76	0.875	14.00	6	7/8	50-60
12	SLCE12	26.96	13.20	12.75	14.32	13.30	16.64	0.85	18.58	17.66	0.875	16.25	8	7/8	50-60
14	SLCE14	33.67	15.30		16.40	15.44	20.25	1.20	21.68	19.98	0.875	18.75	10	7/8	55-65
16	SLCE16	41.67	17.40		18.50	17.54	22.45	1.21	23.65	21.95	0.875	21.00	12	7/8	55-65
18	SLCE18	49.50	19.50		20.60	19.64	24.75	1.25	25.79	24.09	0.875	23.25	12	7/8	55-65
20	SLCE20	61.17	21.60		22.70	21.74	27.00	1.34	28.16	26.46	0.875	25.50	14	7/8	55-65
24	SLCE24	79.33	25.80		26.90	25.94	31.50	1.46	32.70	31.00	0.875	30.00	16	7/8	55-65
30	SLCE30	198.00	32.00		33.29	32.17	38.42	2.00	41.92	39.92	1.125	36.88	20	1.00	65-75
36	SLCE36	248.00	38.30		39.59	38.47	46.00	2.00	48.78	46.78	1.125	43.75	24	1.00	65-75

ONE-LOK SLCE was previously referred to as model SLC

P\* Dim shows OD after head is broken/removed.



Sizes 4" - 12" are UL approved  
 Sizes 4" - 12" are FM approved for 150 psi on AWWA C900 pipe and have been tested in accordance with ASTM F1674.