

Fig. 264 (Formerly Afcon Fig. 707)

Adjustable Pipe Saddle Support

Size Range: 2 1/2" through 36"

Material: Cast iron saddle, locknut nipple and special cast iron reducer, assembled.

Finish: ☐ Plain or ☐ Zinc Plated (Nipple Reducer Assembly cannot be Hot-Dipped.)

Service: Stanchion type support where vertical adjustment of **stationary** pipe is required.

Approvals: Complies with Federal Specification A-A-1192A (Type 38), WW-H-171-E (Type 39), ANSI/MSS SP-69 and MSS SP-58 (Type 38).

Installation: Adjustment is obtained by turning the locknut nipple. The lower end of the nipple is staked, upsetting the threads to prevent separation of nipple and coupling during adjustment.

Features:

- Vertical adjustment of approximately 4 1/2"
- Saddle supports a broad range of pipe sizes

Ordering: Specify pipe size to be supported, figure number, name and finish.

Order Separately: Figure 63T Square Cut Threaded End Stanchion. Specify "H" and pipe size to be supported by Figure 264.



FIG. 264: DIMENSIONS (IN) • LOADS (LBS) • WEIGHT (LBS)								
Pipe Size	Weight		A	B	D	E		Max Load
	Complete	Saddle Only				Min	Max	
2½	9.0	4.8	2½	3½	1½	8	13	1,800
3	9.2	5.0		3¾		8¼	13¼	
3½	9.4	5.2		4		8½	13½	
4	15.0	7.6	3	4¼	2½	9¼	14	3,800
5	16.7	8.3		4⅝		10	14¾	
6	17.7	10.3		5½		10½	15¼	
8	20.2	12.8		6⅞		11¾	16½	
10	25.2	17.8		8½		13½	18¼	
12	29.0	21.6		9⅝		15	19¾	
14	40.2	38.0	4	10⅝	3	16¼	20¾	5,300
16	53.2	42.0		12⅜		17¾	22¼	
18	70.8	51.0	6	13⅞	3½	19½	24	6,700
20	104.8	85.0		15⅜		21	25½	
22	121.0	98.0		15½		21⅝	25⅜	
24	137.0	110.0		17⅝	4	23¾	28¼	7,300
26	154.0	130.0		18½		24⅝	28⅜	
30	170.0	150.0		21⅝		27	31½	
32	181.0	161.1		22½		28¼	32¾	
36	249.0	229.0		24½		30¼	34¾	

* The special cast iron reducer may be furnished with a hexed shaped smaller end.

* Standard Wall Pipe

The above load ratings are applicable to the saddle only and are not applicable to the stanchion or other means used to support the saddle.




Fig. 63, Type T

Square Cut Threaded End for use with Figure 264 or 265 Adjustable Pipe Saddle Support

PROJECT INFORMATION		APPROVAL STAMP
Project:		☐ Approved
Address:		☐ Approved as noted
Contractor:		☐ Not approved
Engineer:		Remarks:
Submittal Date:		
Notes 1:		
Notes 2:		