

Vic®-End II End of Run Fitting

SERIES 67



SEE VICTAULIC PUBLICATION 10.01 FOR DETAILS

The No. 67, Vic®-End II, End of Run Fitting is the fast, easy, economical way to end a branch line. The fitting installs easily with standard FireLock® couplings and allows direct head connection, sprigs or drops.

Available in 1 ¼, 1 ½, 2 and 2 ½"/32-65 mm sizes, the fittings can be supplied with ½, ¾, or 1" 15, 20 or 25 mm female threaded (NPT) outlet (BSPT option available).

The 90° reducing outlet fitting is UL/ULC Listed and FM Approved for a maximum rated working pressure of 500 psi/3450 kPa.



MATERIAL SPECIFICATIONS

Housing: Ductile iron conforming to ASTM A-536, grade 65-45-12, painted Orange Enamel. Ductile iron conforming to ASTM A-395, grade 65-45-15, is available upon special request.

- **Optional:** Galvanized – hot dipped.

Outlet: NPT

- **Optional:** BSPT

DIMENSIONS, PERFORMANCE

Nominal Size Inches/mm			C to E Inches/mm	Approx. Weight Ea Lbs./Kg	Equivalent Feet/meters of pipe
1 ¼ 32	×	½ NPT	2.38	1.4	2.8
		15 NPT	61	0.6	0.9
		¾ NPT	2.38	1.4	2.8
		20 NPT	61	0.6	0.9
1 ½ 40	×	1 NPT	2.38	1.4	2.8
		25 NPT	61	0.6	0.9
		½ NPT	2.50	1.6	2.9
		15 NPT	64	0.7	0.9
2 50	×	¾ NPT	2.50	1.6	2.9
		20 NPT	64	0.7	0.9
		1 NPT	2.50	1.6	2.9
		25 NPT	64	0.7	0.9
2 ½ 65	×	½ NPT	2.75	1.7	4.0
		15 NPT	70	0.8	1.2
		¾ NPT	2.75	1.7	4.0
		20 NPT	70	0.8	1.2
	×	1 NPT	2.75	1.7	4.0
		25 NPT	70	0.8	1.2
	×	½ NPT	3.00	2.0	5.7
		15 NPT	76	0.9	1.7
		¾ NPT	3.00	2.0	5.7
		20 NPT	76	0.9	1.7
	×	1 NPT	3.00	2.0	5.7
		25 NPT	76	0.9	1.7

JOB/OWNER

System No. _____

Location _____

CONTRACTOR

Submitted By _____

Date _____

ENGINEER

Spec Sect _____ Para _____

Approved _____

Date _____

www.victaulic.com

VICTAULIC IS A REGISTERED TRADEMARK OF VICTAULIC COMPANY. © 2007 VICTAULIC COMPANY. ALL RIGHTS RESERVED. PRINTED IN THE USA

REV_D



10.21_1

Vic®-End II End of Run Fitting

SERIES 67

WARRANTY

Refer to the Warranty section of the current Price List or contact Victaulic for details.

NOTE

This product shall be manufactured by Victaulic or to Victaulic specifications. All products to be installed in accordance with current Victaulic installation/assembly instructions. Victaulic reserves the right to change product specifications, designs and standard equipment without notice and without incurring obligations.

WARNING**WARNING**

- This product must be installed by an experienced, trained installer, in accordance with the instructions provided with each valve. These instructions contain important information.

Failure to follow these instructions may result in serious personal injury, property damage, or valve leakage.

If you need additional copies of this product literature or the valve installation instructions, or if you have any questions about the safe installation and use of this device, contact Victaulic Company, P.O. Box 31, Easton, PA 18044-0031 USA, Telephone: 001-610-559-3300.



WCAS-7GNF4Y

For complete contact information, visit www.victaulic.com

10.21 3209 REV D UPDATED 7/2008

VICTAULIC IS A REGISTERED TRADEMARK OF VICTAULIC COMPANY. © 2007 VICTAULIC COMPANY. ALL RIGHTS RESERVED. PRINTED IN THE USA

10.21

