

MODEL RVW

(17-400 SERIES)

IMPORTANT

This valve is designed for the following service applications in accordance with "ANSI Z21.22 Relief Valves and Automatic Gas Shutoff Devices" and "CSA 4.4" for hot water supply systems. A PRESSURE RELIEF VALVE is for protection against excessive pressure. If this condition develops, the valve will open and discharge water.

INSTALLATION INSTRUCTIONS

1. Do not install a valve, reducing coupling, or restriction of any kind between the relief valve and vessel.
2. To avoid water damage, the outlet of the valve shall terminate at a point of drainage. The termination of the discharge line shall be downward and not be directly connected to a sewer line.
3. The discharge piping must terminate with a plain end which is not threaded and is constructed of a material suitable for exposure to temperatures of 375°F or greater.
4. Do not install a valve, reducing coupling or restriction of any kind in the the discharge piping. Discharge piping must be independently supported or so arranged as to avoid undue stress on the relief valve.
5. Actual operating pressure should not exceed that of the pressure stamped on valve minus 10 psi or 25% of the set pressure, whichever is greater. Pressures are factory set and are not adjustable.

MAINTENANCE INSTRUCTIONS

This valve is designed to give years of satisfactory service when installed and maintained properly.

THE VALVE SHOULD BE MANUALLY OPERATED AT LEAST ONCE EVERY 6 MONTHS, however, prior to doing so, it should be determined that the outlet is properly connected to discharge piping, otherwise, personal injury or property damage could result.

To actuate the valve, hold the trip lever fully open for about 5 seconds in order to flush the valve seat free of any sediment, then permit the valve check to close.

Conbraco Industries nor its agents assume any liability for valves improperly installed or maintained.

WARNING! This product contains chemicals known to the State of California to cause cancer and birth defects or other reproductive harm: (California law requires that this warning be given to the consumer in the State of California.) For more information visit www.apollovalves.com.

THIS PRODUCT MEETS THE REQUIREMENTS OF THE EPA SAFE DRINKING WATER ACT



MANUFACTURED BY CONBRACO INDUSTRIES INC.
1418 S. PEARL ST.
PAGELAND, SC 29728

