


SUBMITTAL INFORMATION

Brass Saddles For C900 PVC - (S902-xxx style)




BRASS SADDLES WITH AWWA TAPS FOR C900 PVC PIPE

Brass alloy body and strap,
meeting ASTM B62, ASTM B584
and AWWA C800

EPDM Rubber O-Ring gasket

Silicon Bronze Bolts and Nuts



**2-Piece
Bolted Design**

PVC PIPE SIZE	ACTUAL O.D.	TAP SIZE	APPROX. WT. LBS.	CATALOG NUMBER	✓ SUBMITTED ITEM(S)
4"	4.80	1/2"	2.8	S902-401	
		3/4"	2.9	S902-403	
		1"	2.8	S902-404	
		1-1/2"	7.5	S902-406	
		2"	6.5	S902-407	
6"	6.90	1/2"	4.5	S902-601	
		3/4"	4.6	S902-603	
		1"	4.5	S902-604	
		1-1/2"	8.5	S902-606	
		2"	8.5	S902-607	
8"	9.05	1/2"	5.3	S902-801	
		3/4"	5.4	S902-803	
		1"	5.3	S902-804	
		1-1/2"	12.5	S902-806	
		2"	12.0	S902-807	
10"	11.10	1-1/2"	12.8	S902-1006	
		2"	12.2	S902-1007	
12"	13.20	1-1/2"	12.9	S902-1206	
		2"	13.6	S902-1207	

FEATURES

- All brass conforms to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS NO C83600 - 85-5-5-5)
- These saddles conform to the design and sizing requirements held by the Uni-Bell Handbook and the AWWA manual M23 for use on PVC pipe
- O-Ring gasket is EPDM rubber, ASTM D2000

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443

Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167

www.fordmeterbox.com

05/07/15

Submitted By: