



1325 Furneaux Road, Plumas Lakes, CA. 95961
 (530) 742-9675
www.placerwaterworks.com

**STANDARD FOR SACRAMENTO COUNTY,
 CITY OF VACAVILLE, CITY OF WEST SACRAMENTO,**

**ARV ENCLOSURE
 2 PIECE TUBE & COVER
 PW/AE218-M**

6" x 8" x 18" TALL VENT TUBE
 WALL THICKNESS 3/16"

3/16" DIAMOND FLOOR PLATE
 20-1/4" x 33-1/4"
 TO FIT FUSH WITH TOP OF CONCRETE BOX
 NOTE: FITS 1730 TRAFFIC RATED BOX

7-1/2" x 9-1/2" x 1-3/4"
 STEEL CAP WELDED ON

1/2" ± AIR GAP
 ALL AROUND

(x2) 3/8" FASTENERS BOLTS
 AND WASHERS

SECURITY BOLT
 DOWN LOCATION

NOTES:

1. ALL PARTS ARE POWDER COATED HUNTER GREEN TO A THICKNESS OF 3-5 MILLS.
2. LOCK NUTS WELDED TO THE UNDERSIDE OF COVER.
3. 5/16" X 1" FLAT BAR FRAME TO INSURE COVER TO REMAIN FLAT.
4. STEEL COVER IS INDIVIDUALLY PACKAGED COMPLETE WITH FASTENING BOLTS DOWN.
5. VENT TUBE IS INDIVIDUALLY PACKAGED AND COMES WITH FASTENERS BOLTS AND WASHERS.
6. ALL WELDING DONE PER AWS SPECIFICATIONS.

CAT#: PW/AE218-M

COPYRIGHTED 2015 PLACER WATERWORK, INC. © ALL RIGHTS RESERVED - FOR DUPLICATION AUTHORIZATION MAY OBTAIN THRU: kkern@placerwaterworks.com

SHEET 1 OF 1

***CB: K.K. 01-20-2015 REV.04**