


CAST IRON THREADED FITTINGS



Class 125 (Standard)



FIGURE 367
Concentric Reducer



| Size | | | | A | | B* | | Unit Weight | |
|-------|-----|-----------|-----|-------|----|--------|----|-------------|-------|
| | | | | | | | | Black | |
| NPS | DN | NPS | DN | in | mm | in | mm | lbs | kg |
| 3/4 | 20 | 1/2 | 15 | 5/8 | 16 | 19/16 | 40 | 0.40 | 0.18 |
| 1 | 25 | 1/2 (Hex) | 15 | 11/16 | 17 | 111/16 | 43 | 0.54 | 0.24 |
| | | 3/4 (Hex) | 20 | 7/16 | 11 | 11/2 | 38 | 0.63 | 0.29 |
| 1 1/4 | 32 | 1/2 | 15 | 9/16 | 14 | 15/8 | 41 | 0.84 | 0.38 |
| | | 3/4 | 20 | 1 | 25 | 21/8 | 54 | 0.90 | 0.41 |
| | | 1 | 25 | 15/16 | 24 | 21/8 | 54 | 1.07 | 0.49 |
| 1 1/2 | 40 | 1/2 | 15 | 1/2 | 13 | 15/8 | 41 | 1.00 | 0.45 |
| | | 3/4 | 20 | 1/2 | 13 | 15/8 | 41 | 1.20 | 0.54 |
| | | 1 | 25 | 1/2 | 13 | 13/4 | 44 | 1.50 | 0.68 |
| | | 1 1/4 | 32 | 1 | 25 | 21/4 | 57 | 1.45 | 0.66 |
| 2 | 50 | 1/2 | 15 | 5/8 | 16 | 2 | 51 | 2.00 | 0.91 |
| | | 3/4 | 20 | 3/4 | 19 | 2 | 51 | 1.90 | 0.86 |
| | | 1 | 25 | 3/4 | 19 | 2 | 51 | 1.83 | 0.83 |
| | | 1 1/4 | 32 | 13/16 | 22 | 21/8 | 54 | 1.78 | 0.81 |
| | | 1 1/2 | 40 | 7/8 | 22 | 23/16 | 56 | 1.98 | 0.90 |
| 2 1/2 | 65 | 1 1/2 | 40 | 3/4 | 19 | 2 | 51 | 3.10 | 1.41 |
| | | 2 | 50 | 1 | 25 | 29/16 | 65 | 2.98 | 1.35 |
| 3 | 80 | 3/4 | 20 | 15/16 | 24 | 21/2 | 64 | 4.31 | 1.95 |
| | | 2 | 50 | 11/16 | 27 | 23/4 | 70 | 3.96 | 1.80 |
| | | 2 1/2 | 65 | 15/16 | 24 | 213/16 | 73 | 4.40 | 2.00 |
| 4 | 100 | 2 | 50 | 13/16 | 30 | 215/16 | 75 | 6.50 | 2.95 |
| | | 2 1/2 | 65 | 13/16 | 30 | 31/8 | 79 | 7.78 | 3.53 |
| | | 3 | 80 | 11/16 | 27 | 31/8 | 79 | 7.01 | 3.18 |
| 5 | 125 | 4 | 100 | 11/16 | 27 | 35/16 | 84 | 10.48 | 4.75 |
| 6 | 150 | 4 | 100 | 11/8 | 29 | 37/16 | 87 | 13.83 | 6.27 |
| | | 5 | 125 | 11/8 | 29 | 39/16 | 90 | 15.53 | 7.04 |
| 8 | 200 | 6 | 150 | 11/4 | 32 | 37/8 | 98 | 29.10 | 13.20 |

* Dimension "B" does not conform to ASME standard.

Note: See following page for pressure-temperature ratings.

| PROJECT INFORMATION | | APPROVAL STAMP | |
|---------------------|--|--|--|
| Project: | | <input type="checkbox"/> Approved | |
| Address: | | <input type="checkbox"/> Approved as noted | |
| Contractor: | | <input type="checkbox"/> Not approved | |
| Engineer: | | Remarks: | |
| Submittal Date: | | | |
| Notes 1: | | | |
| Notes 2: | | | |

CAST IRON THREADED FITTINGS



Anvil standard and extra heavy cast iron threaded fittings are manufactured in accordance with ASME B16.4. Plugs and bushings are manufactured in accordance with ASME B16.14.

NOTE: Figure 367 Concentric Reducers do not meet the overall length requirement of ASME B16.4. All other dimensions are in compliance.



For Listings/Approval Details and Limitations, visit our website at www.anvilintl.com or contact an Anvil Sales Representative.

| Cast Iron Threaded Fittings Pressure - Temperature Ratings | | | | | |
|---|---------------|-----------|------|-----------|------|
| Temperature | | Pressure | | | |
| | | Class 125 | | Class 250 | |
| (°F) | (°C) | psi | bar | psi | bar |
| -20° to 150° | -28.9 to 65.6 | 175 | 12.1 | 400 | 27.6 |
| 200° | 93.3 | 165 | 11.4 | 370 | 25.5 |
| 250° | 121.1 | 150 | 10.3 | 340 | 23.4 |
| 300° | 148.9 | 140 | 9.7 | 310 | 21.4 |
| 350° | 176.7 | 125 | 8.6 | 300 | 20.7 |
| 400° | 204.4 | - | - | 250 | 17.2 |

| Standards and Specifications | | | | | |
|------------------------------|-------------|----------------|--------------|--------------|-----------------|
| | Dimensions | Material | Galvanizing* | Thread | Pressure Rating |
| CAST IRON THREADED FITTINGS | | | | | |
| Class 125 | ASME B16.4 | ASTM A-126 (A) | ASTM A-153 | ASME B1.20.1 | ASME B16.4 |
| Class 250 | ASME B16.4 | ASTM A-126 (A) | ASTM A-153 | ASME B1.20.1 | ASME B16.4 |
| CAST IRON PLUGS AND BUSHINGS | | | | | |
| | ASME B16.14 | ASTM A-126 (A) | ASTM A-153 | ASME B1.20.1 | ASME B16.14 |

* ASTM B 633, Type I, SC 4, may be supplied as alternate zinc coating per applicable ASME B16 product standard.

General Assembly of Threaded Fittings

- 1) Inspect both male and female components prior to assembly.
 - Threads should be free from mechanical damage, dirt, chips and excess cutting oil.
 - Clean or replace components as necessary.
- 2) Application of thread sealant
 - Use a thread sealant that is fast drying, sets-up to a semi hard condition and is vibration resistant. Alternately, an anaerobic sealant may be utilized.
 - Thoroughly mix the thread sealant prior to application.
 - Apply a thick even coat to the male threads only. Best application is achieved with a brush stiff enough to force sealant down to the root of the threads.
- 3) Joint Makeup
 - For sizes up to and including 2" pipe, wrench tight makeup is considered three full turns past handtight. Handtight engagement for 1/2" through 2" thread varies from 4 1/2 turns to 5 turns.
 - For 2 1/2" through 4" sizes, wrench tight makeup is considered two full turns past handtight. Handtight engagement for 2 1/2" through 4" thread varies from 5 1/2 turns to 6 3/4 turns.