

THREADED WATER HAMMER ARRESTORS

www.pppinc.net

ONLY ONE MOVING PART!

WATER HAMMER ARRESTORS ARE SPECIFIED FOR COMMERCIAL, INDUSTRIAL AND RESIDENTIAL USES.

PPP WATER HAMMER ARRESTORS
SPECIFIED FOR MANY
INSTALLATIONS!

A maintenance-free installation is assured when using this type of arrestor...the only moving part is the freemoving piston furnished with "O"ring seals which have been tested for reliability in excess of normal operating ranges.



SC-500A - SC-2000F

FLUID HAMMER IN FLUID TRANSMISSION LINES - a definition.

Fluid Hammer is a series of hydraulic shock waves generated within the confines of a piping system due to the sudden stopping of fluid flow. This condition is caused by fast closing of positive valves incorporated within the system. The effect of fluid hammer is damaging if allowed to exist for any length of time and will result in broken pipes and damage to other components in the system.

U.S. Patent No. 3,633,627

40 Years of outstanding performance










SPECIFICATIONS & INSTALLATIONS



INSTALLATION: May be installed in new or existing plumbing systems with a standard pipe tee. **MAINTENANCE**: Maintenance free – the piston

is the only moving part.

TEMPERATURE RANGE: -40°F to + 212°F

 $(-4.4^{\circ}C \text{ to } + 100^{\circ}C)$

CONSTRUCTION: Barrel-fabricated of type "K" hard drawn copper.

Cap: Copper or Polycarbonate DOW Calibre 2016-15MFR.

Piston and threaded adapter: Machined of free turning brass or polycarbonate DOW Calibre 2016-15MFR.

Seals: "O"rings: EPDM.

Seal Lubricant: Dow-Corning Silicone Compound #111, FDA listed for use in potable water

Nickel Plated: For Salt Water Application. **OPERATING PRESSURE**: Designed to operate on all domestic and commercial systems. Normal operating pressure 0 to 200 P.S.I.G., Max spike pressure 400 P.S.I.G.

PDI SIZING AND SELECTION TABLE

PIPE SIZE	FIXTURE UNITS	CROSS REF. PDI	
1/2"	1-11	Α	
3/4"	12-32	В	
1"	33-60	С	
1 1/4"	61-113	D	
1 1/2"	114-154	Е	
2'"	155-330	F	

Extract from: PDI WH201-06

PROJECT SUBMITTAL

Project:
Contractor:
Engineer:
Date Submitted:
Prepared By:

SIZING INFORMATION

For equipment and fixtures not listed below, size in accordance with load values (WSFU)assigned the same.

Extract from: PDI WH201-06

Extract from: F D1 W11201-00						
FIXTURE	TYPE OF SUPPLY CONTROL	WEIGHT IN FIXTURE UNITS				
		Public Private		Public		
		C.W.	H.W.	C.W.	H.W	
Water Closet	Flush Valve	8	-	5	-	
Water Closet	Flush Tank	5	-	2.5	-	
Pedestal Urinal	Flush Valve	4	-	-	-	
Stall or Wall Urinal	Flush Valve	4	-	-	-	
Stall or Wall Urinal	Flush Tank	2	-	-	-	
Lavatory	Faucet	1 1/2	1 1/2	1	1	
Bathtub	Faucet	2	3	1 1/2	1 1/2	
Shower Head	Mixing Valve	2	3	1	2	
Bathroom Group	Flush Valve Closet	-	-	8	3	
Bathroom Group	Flush Tank Closet	-	-	6	3	
Separate Shower	Mixing Valve	-	-	1	2	
Service Sink	Faucet	3	3	-	-	
Laundry Tubs (1-3)	Faucet	-	-	3	3	
Comb. Fixture	Faucet	-	-	3	3	

DIMENSIONAL AND AIR LOADING DATA

PART NUMBER	A O.A.L.	B N.P.T.	NITROGEN PRELOAD PSI
SC-500A*	6 1/4"	1/2" brass	60
SC-750B*	7 1/4"	3/4" brass	60
SC-1000C	9 1/2"	1" brass	60
SC-1250D	11 3/8"	1" brass	60
SC-1500E	12 3/4"	1" brass	60
SC-2000F	13 3/4"	1" brass	60

Precision Plumbing Products Division of JL Industries, Inc.



<u>|[i</u>ndustries, inc

Airport Business Center 6807 NE 79th Court, Suite E Portland, Oregon 97218

T (503) 256-4010 F (503) 253-8165

www.pppinc.net Rev 09/07