



TO OUR VALUED CUSTOMER:

We hereby certify that to the best of our knowledge and belief that the domestic lead-free fittings supplied to us by Lee Brass and New England Union Company comply with the following standards:

DIMENSION	SPECIFICATIONS
	ANSI/ASME B16.14, B15.15,B16.18 MSS-SP-106 (FLANGES) A-A-5961 (UNION)
THREADS	ANSI/ASME B1.20.1
MATERIAL	ASTM 584-06a (C89833) LEAD FREE Cu = 87.0-91.0% Sn = 4.0-6.0% Pb = 0.10% (Max.) Zn = 2.0-4.0% Ni = 1.0% (Max.) P = 0.05% (Max.) Si = 0.005% (Max.) Al = 0.005% (Max.) S = 0.08% (Max.) Fe = 0.3% (Max.) Sb = 0.25% (Max.) Bi = 1.7-2.7%

Please consider this letter official notification that these fittings meet all applicable state and federal lead-free requirements, and are also certified by NSF to NSF/ANSI 61 Annex G.

Regards,

Charlene Urban
Purchasing
Merit Brass Company



QMI-SAI Global
Certificate No. 8375

P.O. Box 43127 • One Merit Drive • Cleveland, OH 44143

Phone: 216 261 9800 • Toll Free: 800 726 9800 • Fax: 800 726 9880 • www.meritbrass.com • www.mbwebXpress.com

