

## IMPORTANT NOTICE

The **ECAP321** is designed for **VERTICAL** venting applications on **PVC** or **ABS Plastic Pipe ONLY**.

Although it can be used for HORIZONTAL venting applications by extending the pipe from the building structure per the furnace/boiler manufacturers installation instructions, and adding a 90 degree elbow in the Up position. Then install the ECAP321 on to the elbow.

The flue gases will exhaust in the down flow direction.

- Install with at least 10" clearance from roof line
- Installs with standard PVC Cement
- Fits 1.5", 2" and 3" PVC Pipe
- Can be used on both Intake and Exhaust
- Install Exhaust at least 10" above Intake



### SEALED UNIT PARTS CO., INC.

2230 Landmark Place • Allenwood, NJ 08720 USA  
(732) 223-6644 • Fax (732) 223-1617  
www.supco.com • info@supco.com



For use on 3 sizes (1 1/2", 2" & 3")  
for use on plastic vent pipes from  
High Efficiency  
furnace installations with maximum outlet  
temperatures of 212 °F (100 °C)

#### Certification Requirements:

##### PRODUCTS

##### CLASS

3307-02

3307-82

**DRAFT EQUIPMENT Gas Vents**

**DRAFT EQUIPMENT Gas Vents Certified to U.S. Standards**

# ECAP321

##### APPLICABLE REQUIREMENTS

ULC 5636

**Standard for Venting Systems for Gas-Burning Appliances, Categories II, III and IV**

ANSI/UL 1738-2000

**Standard for Venting Systems for Gas-Burning Appliances, Categories II, III and IV**

ANSI Z21.47/

**Gas-Fired Central Furnaces CSA 2.3**



R55-713

### SEALED UNIT PARTS CO., INC.

2230 Landmark Place • Allenwood, NJ 08720 USA  
(732) 223-6644 • Fax (732) 223  
www.supco.com • info@supco.com