



WORKING PRESSURE  
150 PSI COLD WORKING PRESSURE - C.W.P.

TEST PRESSURE  
1.5 TIMES COLD WORKING PRESSURE - C.W.P.

- |   |                 |    |                |    |                      |
|---|-----------------|----|----------------|----|----------------------|
| 1 | BODY            | 9  | GUIDE BUSHING  | 18 | LOCK NUT             |
| 2 | COVER           | 10 | FLOAT ARM      | 20 | GUIDE SHAFT          |
| 3 | BAFFLE          | 11 | ORIFICE BUTTON | 28 | PIPE PLUG            |
| 4 | SEAT            | 12 | PIVOT PIN      | 33 | CLEVIS               |
| 5 | FLOAT           | 13 | RETAINING RING | 34 | LOCK WASHER          |
| 6 | GASKET          | 14 | PIPE PLUG      | 35 | GUIDE SHAFT RETAINER |
| 7 | COVER BOLT      | 16 | PLUG           | 36 | PIPE PLUG            |
| 8 | RETAINING SCREW | 17 | FLOAT RETAINER |    |                      |

SEE DRAWING NO. VM-801A-M FOR STANDARD MATERIALS OF CONSTRUCTION.  
SEE DRAWING NO. VM-801ADISV-M FOR SUPER VALVE MATERIALS OF CONSTRUCTION.

WASTEWATER COMBINATION AIR VALVE

DATE 4-8-14

**VALMATIC**

VALVE AND MANUFACTURING CORP.

DRWG. NO.

VMC-801A