



# SUBMITTAL INFORMATION

Brass Bushings for Corporation Stop Inlets - (BBAA-xx-NL style)



**MALE AWWA TAPER OUTSIDE THREAD BY FEMALE AWWA TAPER INSIDE THREAD**



DESCRIPTION		APPROX. WT. LBS.	CATALOG NUMBER	✓ SUBMITTED ITEM(S)
OUTSIDE THREAD SIZE AND TYPE	INSIDE THREAD SIZE AND TYPE			
3/4" Male AWWA Taper Thread	1/2" Female AWWA Taper Thread	0.30	BBAA-31-NL	
1" Male AWWA Taper Thread	3/4" Female AWWA Taper Thread	0.45	BBAA-43-NL	
1-1/4" Male AWWA Taper Thread	3/4" Female AWWA Taper Thread	1.00	BBAA-53-NL	
1-1/2" Male AWWA Taper Thread	3/4" Female AWWA Taper Thread	1.25	BBAA-63-NL	
1-1/2" Male AWWA Taper Thread	1" Female AWWA Taper Thread	1.25	BBAA-64-NL	
2" Male AWWA Taper Thread	3/4" Female AWWA Taper Thread	2.20	BBAA-73-NL	
2" Male AWWA Taper Thread	1" Female AWWA Taper Thread	2.10	BBAA-74-NL	
2" Male AWWA Taper Thread	1-1/4" Female AWWA Taper Thread	1.80	BBAA-75-NL	
2" Male AWWA Taper Thread	1-1/2" Female AWWA Taper Thread	1.50	BBAA-76-NL	

## FEATURES

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (ASTM B584, UNS C89833)
- The product has the letters "NL" cast into the main body for lead-free identification
- Certified to NSF/ANSI Standard 61 and NSF/ANSI Standard 372 where applicable
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS C83600, 85-5-5-5)
- Hexagonal wrench flats are provided for proper installation

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



**The Ford Meter Box Company, Inc.**

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443

Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167

www.fordmeterbox.com

10/20/16

Submitted By: