

SUBMITTAL INFORMATION

Corporation Stop Replacement Piece - *(F40-x-NL style)*



AWWA/CC TAPER THREAD INLET BY MALE IRON PIPE THREAD OUTLET



Description		Length	Approx. Wt. Lbs	Part Number	✓ Submitted Item(s)
Inlet Size	Outlet Size				
1/2"	1/2"	2-1/8"	0.3	F40-1-NL	
3/4"	3/4"	2-5/8"	0.4	F40-3-NL	
1"	1"	2-5/8"	0.6	F40-4-NL	
1-1/2"	1-1/2"	3-13/16"	1.4	F40-6-NL	
2"	2"	4-1/8"	2.6	F40-7-NL	

FEATURES

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (ASTM B584, UNS C89833)
- The product has the letters “NL” cast into the main body for lead-free identification
- Certified to NSF/ANSI Standard 61 and NSF/ANSI Standard 372 where applicable
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS C83600, 85-5-5-5)
- Body design provides hexagonal wrench flats for proper installation
- Replaces F400 corporation stops and FB400 ballcorps

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.

The Ford Meter Box Company, Inc.
P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443
Phone: 260-563-3171 / Fax: 800-826-3487
Overseas Fax: 260-563-0167
www.fordmeterbox.com

06/03/14

Submitted By: