


Directions for installing the Sauermann Pump Safety for Mr. Slim P-Series Applications.

1. In order to cycle the unit off via the pump safety you will need to break terminal number 1 12 volt D.C. leg feeding the outdoor unit.



2. Cut the transmission line at terminal 1 that runs from the indoor unit (TB4) to the outdoor unit (TB3) and wire the pump safety in series with it.

