Safety Stations with Eye/Face Wash



G1996 Safety Station with Eye/Face Wash, All-Stainless Steel Construction

Application: All-stainless steel combination eye/face wash and shower safety station. Stainless steel construction is ideal for highly corrosive environments and clean room applications. Two large FS-Plus[™] spray-type outlet heads deliver a flood of water for rinsing eyes and face.

Shower Head: 10" diameter stainless steel.

Shower Valve: 1" IPS Type 316 stainless steel stay-open ball valve. Valve has stainless steel ball and Teflon® seals. Furnished with stainless steel actuating arm and 29" stainless steel pull rod.

Spray Head Assembly: Two FS-Plus™ spray heads. Each head has a "flip top" dust cover, internal flow control and filter to remove impurities from the water flow.

Eye/Face Wash Bowl: 11-1/2" diameter stainless steel.

Eye/Face Wash Valve: 1/2" IPS Type 316 stainless steel stayopen ball valve. Valve has stainless steel ball and Teflon[®] seals.

Pipe and Fittings: Schedule 40 Type 304 brushed stainless steel. Furnished with orange polyethylene covers for vertical piping for high visibility and corrosion resistance.

Supply: 1-1/4" NPT female top or side inlet.

Waste: 1-1/4" NPT female outlet.

Sign: Furnished with ANSI-compliant identification sign.

Quality Assurance: Valve and spray head assemblies are factory assembled and water tested prior to shipment.

Available Options

BC Stainless steel cover for eye/face wash bowl.

FC20 Regulates shower flow rate to 20 GPM.

AP275-100 Electric Light and Alarm Horn

Light and alarm horn summon assistance when eye/face wash or shower is activated.

AP250-015 Modesty Curtain

Modesty curtain for mounting on safety station.

TMV G3800LF thermostatic mixing valve precisely blends hot and cold water to deliver warm (tepid) water as required by ANSI Z358.1-2014.





Listed 8116. Units have been tested to and comply with ANSI Z358.1-2014 and the Uniform Plumbing Code. C



Units have been tested to and comply with ANSI 7358.1-2014.


ETL Listed 101496.

Guardian Equipment Chicago, IL 60642

312 447 8100 телерноме 1140 N North Branch St 312 447 8101 FACSIMILE gesafety.com







Guardian Equipment 1140 N North Branch St Chicago, IL 60642

312 447 8100 теlephone 312 447 8101 FACSIMILE gesafety.com

Listed 8116. Units have been tested to and comply with ANSI Z358.1-2014 and the Uniform Plumbing Code.

Ųρ



