Rinnai Grundfos GTK15 Pump Kit

Grundfos 15-55 pump with timer and internal check valve

Part Number: GTK15

6 Ft (2 m) electrical cord

Kit Contents

•

•







(Images for illustrative purposes only)

Wire Nuts (Qty 5)Flange kit	pump (includes in-line 4 Amp glass fuse)
 Rinnai Circ-Logic™ Manual 	
Specifications	
Housing Material	Stainless Steel with Check Valve
Flow Range	20 GPM
Head Range	17 Ft (5 m)
Max Liquid Temperature	150° F (65° C)
Maximum System Pressure	145 PSI
Input Voltage	115 V
Frequency	60 Hz
Max Amperage	0.75 A
Connection Size	3/4" Flange
Weight (Pump/Flange Kit Combined)	8.9 lbs. (4 kg)
Pipe Length	
Equivalent pipe length using Grund 120°F (49° C) = Up to 200 Ft (61 m	
Equivalent pipe length includes sup	ply piping, return piping and fittings. The alculate the total equivalent pipe length of
Warranty	Manufacturer's Warranty Applies
Timer Control	
Designed to turn the pump on and off a	at preset times.
Shortest Switching Interval	15 Minute Increments
Protection	Clear plastic cover for dust and moisture protection of clock face

Modes

Requirements

Grundfos GTK15 Kit must be used with Rinnai Tankless Water Heaters utilizing Rinnai Circ-Logic™.

Timer, On (Override) and Off (Override)



Rinnai GTK15 Pump Kit

Pump Performance Curve



Electrical Diagram



Wiring Table

•		
Description	GTK15 (Timer)	Supplied Line Cord
+115VAC	Brown (Br)	Black (Bk)
Neutral	Gray (Gy)	White (W)
Ground	Green (Gn)	Green (Gn)
	GTK15 (Pump)	Rinnai Circ-Logic™
+115VAC (Circ-Logic™)	Red (R)	Black (Bk)
Neutral (Circ-Logic™)	Blue (BI)	White (W)

Rinnai.

Learn more about Rinnai high-performance Commercial and Residential Tankless Water Heaters, Hybrid Tank-Tankless Water Heaters, Boilers, Vent-Free Fan Convectors and EnergySaver® Direct Vent Wall Furnaces at:

rinnai.us | rinnai.ca

1-800-621-9419

Rinnai America Corporation • 103 International Drive, Peachtree City, GA 30269

1-800-621-9419 • rinnai.us

©2017 Rinnai America Corporation. Rinnai America Corporation continually updates materials, and as such, content is subject to change without notice. Local, state, provincial federal and national fuel gas codes must be adhered to prior to and upon installation.

GTK15-SP 3/2017