

SUBMITTAL INFORMATION






ANGLE BALL VALVE BY ANGLE CHECK VALVE (5/8" X 3/4" METER)

DOUBLE PURPOSE UNION SWIVEL INLET AND OUTLET



Coppersetter Part Number

HEIGHT	APPROX.	CATALOG NUMBER	SUBMITTED
(INCHES)	WT. LBS.	(INSERT SERVICE LINE CONN. SIZE)	ITEM(S)
7	6.0	VBH72-7W-11-xx-NL	
9	6.2	VBH72-9W-11-xx-NL	
12	6.4	VBH72-12W-11-xx-NL	
15	6.6	VBH72-15W-11-xx-NL	
18	7.3	VBH72-18W-11-xx-NL	
21	7.5	VBH72-21W-11-xx-NL	
24	7.8	VBH72-24W-11-xx-NL	
27	8.0	VBH72-27W-11-xx-NL	
30	8.3	VBH72-30W-11-xx-NL	
33	8.6	VBH72-33W-11-xx-NL	
36	8.8	VBH72-36W-11-xx-NL	
39	9.1	VBH72-39W-11-xx-NL	
42	9.4	VBH72-42W-11-xx-NL	



Service Line Size

INLET	OUTLET	SERVICE LINE CONN. SIZE	SUBMITTED ITEM(S)
3/4" D.P. Swivel	3/4" D.P. Swivel	33	
1" D.P. Swivel	1" D.P. Swivel	44	

FEATURES

- All brass that comes in contact with potable water conforms to AWWA standard C800 (UNS NO C89833)
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B-62 and ASTM B-854, UNS NO C83600 - 85-5-5-5)
- The product has the letters "NL" cast into the main body for proper identification.
- Saddle nuts hold the meter in place for tightening.
- Bracing Eye is standard on all 70 Series Coppersetters.
- Tie Bar is standard for 18" and taller Coppersetter heights (72 Series).
- Double Purpose Union Swivels will accommodate male iron pipe threads or flare copper.
- 13/16" Copper Risers provide more flow capacity.
- All Ford Setters are assembled with lead-free solder.
- Copper conforms to ASTM B-75, Copper Alloy #122.

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443 Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167 http://www.fordmeterbox.com

10/10/12

Submitted By: