

SUBMITTAL INFORMATION






ANGLE KEY VALVE BY ANGLE CARTRIDGE DUAL CHECK VALVE (5/8" X 3/4" METER)

DOUBLE PURPOSE UNION SWIVEL INLET AND OUTLET



Coppersetter Part Number

HEIGHT (INCHES)	APPROX. Wt. Lbs.	CATALOG NUMBER (INSERT SERVICE LINE CONN. SIZE)	✓ SUBMITTED ITEM(S)
9	6.2	VHC72-9W-11-xx-NL	
12	6.4	VHC72-12W-11-xx-NL	
15	6.6	VHC72-15W-11-xx-NL	
18	7.3	VHC72-18W-11-xx-NL	
21	7.5	VHC72-21W-11-xx-NL	
24	7.8	VHC72-24W-11-xx-NL	
27	8.0	VHC72-27W-11-xx-NL	
30	8.3	VHC72-30W-11-xx-NL	
33	8.6	VHC72-33W-11-xx-NL	
36	8.8	VHC72-36W-11-xx-NL	
39	9.1	VHC72-39W-11-xx-NL	
42	9.4	VHC72-42W-11-xx-NL	



Service Line Size

OUTLET	SERVICE LINE CONN. SIZE	✓ SUBMITTED ITEM(S)
3/4" D.P. Swivel	33	
1" D.P. Swivel	44	
	3/4" D.P. Swivel	OUTLET CONN. SIZE 3/4" D.P. Swivel 33

FEATURES

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (UNS NO C89833)
- The product has the letters "NL" cast into the main body for proper identification
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B-62 and ASTM B-584, UNS NO C83600 - 85-5-5-5)
- Saddle Nuts hold the meter in place for tightening
- Bracing eye is standard on all 70 Series Coppersetters
- Tie Bar is standard for 21" and taller Coppersetter heights (VHC72 Series)
- Double Purpose Union Swivels will accommodate male iron pipe threads or flare copper
- 13/16" Copper Risers provide more flow capacity
- Copper conforms to ASTM B-75, Copper Alloy #122
- All Ford Setters are assembled with lead-free solder

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443 Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167 http://www.fordmeterbox.com

02/20/13

Submitted By: