

UPBA-481B* ½"-3"

Brass Ball Valve For Potable Water Two Piece Full Port 200 psig @ 250°F† Press x Press Ends With Extension Stem & Memory Stop Blow-Out Proof Stem

IAPMOR&T R	Tested and Certifited by IAMPO R&T to NSF/ANSI 61 and NSF/ANSI 372 for Lead Free Compliance

MATERIALS LIST

ITEM	PART	MATERIALS	ASTM SPEC.						
1	Body	Brass, Forged	B283 C27450						
2	Tailpiece	Brass, Forged	B283 C27450						
3	Ball	Brass, Chrome Plated	B283 C27450						
4	Ball Seat	PTFE	Commercial						
5	Stem	Brass, Forged	B283 C27450						
6	Stem O-Ring	Buna-N	D2000						
7	Thrust Washer	PTFE	Commercial						
8	Gland Nut	Brass	B124						
9	Packing	PTFE	Commercial						
10	Handle	Zinc Plated Steel	Commercial						
11	Handle Bolt	Zinc Plated Steel	Commercial						
12	Tube O-Ring	EPDM	D2000						
13	Stem Stop Plate	Zinc Plated Steel	Commercial						
14	Internal Extension Tube	Zinc Plated Steel	Commercial						
15	External Extension Tube	Zinc Plated Steel	Commercial						
16	Upper Stem Adaptor	Zinc Plated Steel	Commercial						
17	Memory Stop	Zinc Plated Steel	Commercial						
*Ultra Press Valves are designed and qualified for use in copper tubing									



*Ultra Press Valves are designed and qualified for use in copper tubing systems only, Types K, L & M per ASTM B88.

DIMENSIONS

	UNITS	1/2" DN15	3/4" DN20	1" DN25	1-1/4" DN32	1-1/2" DN40	2" DN50	2-1/2" DN65	3" DN80
А	INCHES	0.51	0.76	0.98	1.26	1.50	2.01	2.48	2.95
	mm	13	19	25	32	38	51	63	75
В	INCHES	3.16	3.71	4.28	5.20	6.31	7.44	11.92	14.07
	mm	80	94	109	132	160	189	303	357
С	INCHES	1.63	1.92	2.18	2.75	3.40	3.96	5.96	7.04
	mm	41	49	55	70	86	101	151	179
D	INCHES	3.87	4.26	4.46	4.71	4.87	5.38	6.19	6.37
	mm	98	108	113	120	124	137	157	162
E	INCHES	3.15	4.33	4.33	5.12	5.12	6.89	7.87	7.87
	mm	80	110	110	130	130	175	200	200
G	INCHES	1.52	1.73	2.31	3.16	3.49	4.28	8.17	9.86
	mm	39	44	59	80	89	109	208	250
Cv		18	40	72	112	161	287	448	645

†Non-Shock

Note: Lead free refers to the wetted surface of the pipe, fittings and fixtures in potable water systems that have a weighted average lead content $\leq 0.25\%$. Source: California Health and Safety Code (116875).

