

Model 450DA

Double Check Detector Assembly

Application

Designed for installation on water lines in fire protection systems to protect against both backsiphonage and backpressure of polluted water into the potable water supply. Assembly shall provide protection where a potential health hazard does not exist.

Standards Compliance

(Unless otherwise noted, applies to sizes 4" thru 10")

- ASSE® Listed 1048
- · CSA® Certified (4" & 6")
- · AWWA Compliant C 510, and C550
- UL® Classified
- · C-UL® Classified
- FM® Approved
- NYC MEA 26-00-M VOL 3
- Approved by the Foundation for Cross Connection Control and Hydraulic Research at the University of Southern California
- Meets the requirements of NSF/ANSI/CAN 61*
 *(0.25% MAX. WEIGHTED AVERAGE LEAD CONTENT)

Materials

Main valve body
Access covers
Coatings
Ductile Iron ASTM A 536 Grade 4
Ductile Iron ASTM A 536 Grade 4
FDA Approved fusion epoxy finish
Stainless Steel, 300 Series

Elastomers EPDM (FDA approved)
Buna Nitrile (FDA approved)

Polymers NORYL™

Springs Stainless Steel, 300 series

Features

Sizes: 4", 6", 8", 10"

Maximum working water pressure 175 PSI
Maximum working water temperature 140°F
Hydrostatic test pressure 350 PSI

End connections (Grooved for steel)

AWWA C606

(Flanged) ANSI B16.42 Class 150

LEAD FREE NSF/ANSI/CAN 6

Options

(Suffixes can be combined)

- □ with OS & Y gate valves (standard)
- ☐ L less shut-off valves (grooved body connections)
- □ LM less water meter
- □ with gpm meter (standard)
- ☐ CFM with cu ft/min meter
- ☐ G with groove end gate valves
- ☐ FG with flanged inlet gate connection and grooved

outlet gate connection


- ☐ FSC with epoxy coated wye type strainer (flanged only)
- $\hfill \square$ BG with grooved end butterfly valves with integral
 - supervisory switches
- $\ \square$ BF with flanged end butterfly valves with integral
- supervisory switches
- ☐ PI with Post Indicator Gate Valve

Accessories

- ☐ Repair kit (rubber only)
- ☐ Thermal expansion tank (Model XT)
- ☐ Valve setter (Model FLS or MJS or MJFS)
- ☐ Gate valve tamper switch (OSY-40)
- ☐ QT-SET Quick Test Fitting Set

Dimensions & Weights (do not include pkg.)

| l | | WEIGHT | | | | | | | | | | |
|------------------------|-----|---------------------------|-----|-----------------------|-----|-----------------------|-----|-----------------------|-----|-----------------------|-----|--|
| MODEL 450DA SIZE | | LESS SHUTOFF VALVES | | OS&Y GATE (GXF) | | OS&Y GATE (GXG) | | WITH BFLY (GXF) | | WITH BFLY (GXG) | | |
| in. | mm | lbs. | kg | lbs. | kg | lbs. | kg | lbs. | kg | lbs. | kg | |
| 4 | 100 | 105 | 48 | 295 | 134 | 271 | 123 | 175 | 79 | 153 | 69 | |
| 6 | 150 | 174 | 79 | 474 | 215 | 452 | 205 | 278 | 126 | 248 | 112 | |
| 8 | 200 | 402 | 182 | 878 | 398 | 824 | 374 | 592 | 269 | 546 | 248 | |
| 10 | 250 | 420 | 191 | 1076 | 488 | 1018 | 462 | 694 | 315 | 636 | 288 | |



| | | | DIMENSIONS (approximate) | | | | | | | | | | | | | | |
|------------------------|-----|----------|--------------------------|--------------------------|------|--------------------------|------|--------------------------|-----|-------------------|------|---------------------|-----|--------------------------|-----|-----|-----|
| MODEL 450DA SIZE | | А | | B WITH GATE VALVES | | B WITH BFLY VALVES | | B LESS GATE VALVES | | C OS&Y OPEN | | C OS&Y CLOSED | | C WITH BFLY VALVES | | D | |
| in. | mm | in. | mm | in. | mm | in. | mm | in. | mm | in. | mm | in. | mm | in. | mm | in. | mm |
| 4 | 100 | 18 5/16 | 465 | 30 | 762 | 27 3/4 | 705 | 21 | 533 | 22 3/4 | 578 | 18 1/4 | 460 | 9 | 229 | 8 | 203 |
| 6 | 150 | 18 11/16 | 475 | 35 1/2 | 902 | 32 1/8 | 816 | 25 | 635 | 30 1/8 | 765 | 23 3/4 | 603 | 10 1/4 | 260 | 10 | 254 |
| 8 | 200 | 29 | 737 | 46 | 1168 | 42 9/16 | 1081 | 34 7/16 | 845 | 37 3/4 | 959 | 29 1/4 | 743 | 12 | 305 | 13 | 330 |
| 10 | 250 | 29 | 737 | 47 1/2 | 1207 | 47 1/2 | 1207 | 34 7/16 | 845 | 45 3/4 | 1162 | 35 3/8 | 899 | 13 | 330 | 13 | 330 |

Zurn Industries, LLC | Wilkins


1747 Commerce Way, Paso Robles, CA U.S.A. 93446 Ph. 855-663-9876, Fax 805-238-5766

In Canada | Zurn Industries Limited


7900 Goreway Drive, Unit 10, Brampton, Ontario L6T 5W6, 877-892-5216 www.zurn.com

Rev. J Date: 2/21 Document No. BF-450DA Product No. Model 450DA

MODEL 450DA 4" & 6" (STANDARD & METRIC)




MODEL 450DA 8" & 10" (STANDARD & METRIC)



Typical Installation

Local codes shall govern installation requirements. To be installed in accordance with the manufacturer's instructions and the latest edition of the Uniform Plumbing Code. Unless otherwise specified, the assembly shall be mounted above adequate drains with sufficient side clearance for testing and maintenance. The installation shall be made so that no part of the unit can be submerged.

| Capacity thru Schedule 40 Pipe (GPM) | | | | | | | | | |
|--------------------------------------|----------|------------|-----------|-----------|--|--|--|--|--|
| Pipe size | 5 ft/sec | 7.5 ft/sec | 10 ft/sec | 15 ft/sec | | | | | |
| 2 1/2" | 75 | 75 112 | | 224 | | | | | |
| 3" | 115 | 173 | 230 | 346 | | | | | |
| 4" | 198 | 298 | 397 | 595 | | | | | |
| 6" | 450 | 675 | 900 | 1351 | | | | | |
| 8" | 780 | 1169 | 1559 | 2339 | | | | | |
| 10" | 1229 | 1843 | 2458 | 3687 | | | | | |



OUTDOOR INSTALLATION

| | | DIMENSIONS (approximate) | | | | | | | |
|-----|---------|--------------------------|------|--------------------------------|------|--|--|--|--|
| MOD | EL SIZE | A1 SET END END F | TO | A1 SETTER END TO END MJS | | | | | |
| in. | mm | in. | mm | in. | mm | | | | |
| 4 | 100 | 31 5/16 | 795 | 29.313 | 745 | | | | |
| 6 | 150 | 34 3/4 | 884 | 32.75 | 832 | | | | |
| 8 | 200 | 47 | 1194 | 44.625 | 1133 | | | | |
| 10 | 250 | 51 | 1295 | 47 | 1194 | | | | |

Specifications

The Double Check Detector Backflow Preventer shall be certified to NSF/ANSI/CAN 61, ASSE® Listed 1048 and supplied with full port OS & Y gate valves. The main body and access cover shall be epoxy coated ductile iron (ASTM A 536 Grade 4), the seat ring and check valve shall be NORYL™, the stem shall be stainless steel (ASTM A 276) and the seat disc elastomers shall be EPDM. The checks shall be accessible for maintenance without removing the device from the line. The Double Check Detector Backflow Preventer shall be a ZURN WILKINS Model 450DA.