

SUBMITTAL INFORMATION






ANGLE KEY VALVE BY ANGLE DUAL CHECK VALVE (1" METER)

PACK JOINT FOR POLYETHYLENE PIPE (PEP) INLET BY DOUBLE PURPOSE UNION SWIVEL OUTLET



Coppersetter Part Number

HEIGHT (INCHES)	Approx. Wt. Lbs.	CATALOG NUMBER	✓ SUBMITTED ITEM(S)
10	9.0	VHH74-10W-61-44-NL	
12	9.1	VHH74-12W-61-44-NL	
15	9.4	VHH74-15W-61-44-NL	
18	9.7	VHH74-18W-61-44-NL	
21	11.2	VHH74-21W-61-44-NL	
24	11.6	VHH74-24W-61-44-NL	
27	11.9	VHH74-27W-61-44-NL	
30	12.2	VHH74-30W-61-44-NL	
33	12,5	VHH74-33W-61-44-NL	
36	12.8	VHH74-36W-61-44-NL	
39	13.1	VHH74-39W-61-44-NL	
42	13.4	VHH74-42W-61-44-NL	



Service Line Size

INLET	OUTLET	
1" (PEP) P.J.	1" D.P. Swivel	

Note: Ford recommends using insert stiffeners with plastic pipe or tubing

FEATURES

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (ASTM B584, UNS C89833)
- The product has the letters "NL" cast into the main body for lead-free identification
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS C83600, 85-5-5-5)
- Copper conforms to ASTM B88, UNS C12200
- ASSE 1024 approved dual check valve
- Saddle Nuts hold the meter in place for tightening
- All Ford Setters are assembled with lead-free solder
- Bracing Eye is standard on all 70 Series Coppersetters
- Tie Bar is standard for 21" and taller Coppersetter heights (74 Series)
- Double Purpose Union Swivels will accommodate male iron pipe threads or flare copper
- 1-1/8" Copper Risers provide more flow capacity

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443 Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167 www.fordmeterbox.com

04/30/14

Submitted B	y
-------------	---