

Air-Cooled Engines


- Model 6482
- Model 6483
- Model 6484
- Model 6485
- Model 6003
- Model 6004



DESCRIPTION

Scheduled maintenance is a necessity for all standby generators. The Air Cooled Scheduled Maintenance kits offer all the components necessary to perform a complete maintenance on Generac air-cooled generators. Oil will need to be purchased separately based upon the recommendations listed. Maintenance is recommended at every 200 hours or 2 years. If running in a dusty environment, more frequent maintenance may be required. Maintenance intervals may differ per model. Refer to the generator owner's manual for more information.

OIL RECOMMENDATIONS



KIT CONTENTS

Kit Model	6482	6483	6484					6485	6003	6004
Unit Size	8kW (410cc)	11kW (530cc)	13kW (992cc)	14kW (992cc)	15kW (992cc)	16kW (992cc)	17kW (992cc)	20kW (999cc)	7kW (432cc)	6kW (530cc)
Air Filter	•	•	•	•	•	•	•	•	•	•
Oil Filter	•	•	•	•	•	•	•	•	•	•
Spark Plug(s)	1	2	2	2	2	2	2	2	1	2
Oil Funnel	•	•	•	•	•	•	•	•	•	•
Chamois	•	•	•	•	•	•	•	•	•	•
Reminder Sticker	•	•	•	•	•	•	•	•	•	•

*Contents of kits may vary