## McDaniel Metals

281-987-8400 • 281-987-9494 (fax) 1318 Buschong, Houston, TX 77039 www.mcdanielmetals.com

## **DHZIFRPGCHA**

HORIZONTAL INTERNAL FILTER
RACK FOR DAIKIN DP\*\*G/DM\*\*
AND GOODMAN GPG-APG\*\*\*\*M



- 1. Assemble the filter rack per figure 1 using the screws provided.
- 2. Remove the blower access door.
- 3. Slide the rack into the opening until the back angle touches the interior partition. (Figure 2)
- Push the rack against the exterior wall of the unit, taking care to keep the bottom opening of the filter rack above the bottom lip of the unit. (Figure 3)
- 5. From the inside of the unit screw the filter rack to the side of the machine using the holes in the filter rack flange as a guide, taking care not to strip them.
- 6. Remove the screws and reinsert them from the outside of the unit through the holes in the filter rack.
- 7. Install a 20X25X2 filter.
- 8. Reattach the blower access panel.




Figure 1



Figure 2



Figure 3

## **Parts List**

- 12 Sheet metal screws
- 4 Filter rack sides
- 1- Installation instructions