

# ROMAGRIP™ MJ RESTRAINING GLAND FOR USE ON 14 - 24 INCH DUCTILE IRON PIPE

## SUBMITTAL INFORMATION



## USE

The Romac RomaGrip restraining gland is used for the restraint of mechanical joint ductile iron pipe, valves, fittings, and fire hydrants in water transmission and fire protection lines. The RomaGrip replaces costly concrete thrust blocks, corrodible steel tie rods and clamps. Not for use on plain end mechanical joint fittings. The RomaGrip may be used on cast iron pipe as long as it has the same OD as ductile iron pipe.

**NOTE:** Some initial axial movement may occur in lug style restraints as the lugs seat. Movement is directly related to the size of the piping system and the system pressure. In general terms movement of approximately 0.25 can be expected in restraints under 16". For larger sizes, movement of approximately 0.40 may be seen. If this is critical to your application please contact Romac Engineering for additional information.

## MATERIALS

### GLAND

Ductile (nodular) iron, meeting or exceeding ASTM A 536-84, Grade 65-45-12.

### GASKETS

A standard MJ gasket is used with this fitting. See ANSI/AWWA C111/A21.11 for gasket specs.

### RESTRAINING BOLT

7/8 -9 roll thread, Ductile (nodular) iron, meeting or exceeding ASTM A 536.

### RESTRAINING LUGS

Ductile (nodular) iron, meeting or exceeding ASTM A 536. Heat treated using a proprietary process.

### LUG LOCATORS

Polyurethane, a thermo-set plastic.

### COATINGS

Shop coat applied to the casting for corrosion protection in transit. Fusion bonded Romabond Polyester coated glands and Xylan coated restraining bolts and lugs optional.

## PERFORMANCE

NOMINAL PIPE SIZE	#OF RESTRAINING BOLTS	APPROX. WEIGHT (LBS.)	WORKING PRESSURE (PSI)	TEST PRESSURE (PSI)	MAXIMUM JOINT DEFLECTION
14	10	42.8	350	525	2°
16	12	50.4	350	525	2°
18	12	57.4	250	375	1.5°
20	14	66	250	375	1.5°
24	16	83.3	250	375	1.5°

## UL LISTED

UL listed for cast iron and ductile iron pipe.

*This information is based on the best data available at the date printed above. Please check with Romac for any updates or changes.*



www.romac.com  
21919 20th Avenue SE • Suite 100 • Bothell, WA 98021  
Phone (425) 951-6200 • 1-800-426-9341 • Fax (425) 951-6201