



THE LATERAL CONNECTION SOLUTION®



THE MOST **ADVANCED** NAME IN WATER MANAGEMENT SOLUTIONS™



FITS ANY MAINLINE OR STRUCTURE

Stainless Steel Band




Rubber Sleeve

Gasketed PVC Hub

SPECIFICATIONS

Rubber Sleeve	ASTM F477
Band	301 SS
Screw.	305 SS
Housing.	301 SS
Gasket	ASTM F477

LATERAL



ANY MAINLINE OR STRUCTURE

Allow longer lead times for custom fittings such as cast iron or ductile iron.

INSERTA TEE FITTINGS FOR ALL GRAVITY FLOW PIPE AND MANHOLES

Ductile Iron	Spirolite	Ultra Rib™	Pro 21®
Fiberglass	Hi Q®/Sure-Lok®	PermaLok®	Polyethylene
PVC	Vylon®	Corrugated Metal	Truss®
Ultra Corr™	N-12®	Solflo® Max	A2000®
GOLDFLO®	Kor-Flo™	Concrete	Clay
Weholite®	Asbestos Cement	N-12® HP	SaniTite® HP
DuroMaxx®			

INSERTA TEE construction varies with pipe type and size. For pipe not listed, contact our engineering department.

INSERTA TEE® DESCRIPTION

INSERTA TEE is a three-piece service connection consisting of a PVC hub, rubber sleeve and stainless steel band. INSERTA TEE is compression fit into the cored wall of a mainline and requires no special tooling. INSERTA TEEs are designed to connect 2" (51 mm) through 30" (750 mm) laterals to all known solidwall, profile, closed profile, corrugated pipe and manhole structures manufactured today.

INSERTA TEE FOR NEW & REHAB INSTALLATIONS:

- Reduction in labor hours and pipe materials
- Services to be connected where needed
- No need to disturb backfill
- Matching of the internal radius of your pipe or structure for minimal penetration


INSERTA TEE ELIMINATES THE NEED FOR:

- Glues, epoxies and grout
- Tightening and retightening of bands around mainline
- Awkward gaskets

WHEN SLIPLINING, PIPE BURSTING AND RELINING, INSERTA TEE ALLOWS THE FOLLOWING:

- Simple installation with no special equipment required
- For pipe bursting the connection is made directly into solid wall HDPE pipe

APPLICATIONS



- Sanitary Sewers
- Storm Sewers
- Pipe Bursting (HDPE/PVC)
- Sliplining
- Fold-and-Formed Products
- Cured-In-Place Products
- Manholes
- Wet Wells
- Drainage
- Irrigation
- Catch Basins
- Electrical Vaults



Manholes



Sanitary Sewer



Pipe Bursting



StormTech® Systems



Storm Sewer



Reinforced Concrete Pipe



**HP Ag Mains
Ag Field Drainage
N-12 Ag Mains**

EASY, FAST & WATERTIGHT

DIAMOND BITS

Our diamond bits are of the highest quality to ensure maximum holes per bit. Diamond bits are recommended for concrete, clay, fiberglass and ductile iron.

HOLE SAWS

Our specially designed hole saws allow the user to core fast, smooth and clean holes.

For more detailed information on hole saws, refer to the INSERTA TEE Hole Saws Brochure (#10791).



Handheld Drills



HOLE SAW SIZING CHART

INSERTA TEE Size	Hole Saw Size
2" (51 mm) $\frac{5}{8}$ "	2 $\frac{5}{8}$ " (67 mm)
3" (75 mm)	3 $\frac{3}{4}$ " (95 mm)
4" (100 mm)	4 $\frac{1}{2}$ " (114 mm)
6" (150 mm)	6 $\frac{1}{2}$ " (165 mm)
8" (200 mm)	8 $\frac{3}{4}$ " (222 mm)
10" (250 mm)	10 $\frac{7}{8}$ " (276 mm)
12" (300 mm)	12 $\frac{7}{8}$ " (327 mm)
15" (375 mm)	15 $\frac{13}{16}$ " (402 mm)
18" (450 mm)	19 $\frac{3}{16}$ " (503 mm)
21" (525 mm)	22 $\frac{9}{16}$ " (573 mm)
24" (600 mm)	25 $\frac{5}{16}$ " (643 mm)
27" (675 mm)	28 $\frac{1}{2}$ " (724 mm)
30" (750 mm)	32 $\frac{17}{32}$ " (826 mm)

TESTING INFORMATION*

NORTHWEST TESTING LABORATORY; PORTLAND, OREGON

REFERENCE DOCUMENT: ASTM D3212

A 4" INSERTA TEE was installed into an 8" profile pipe with the following results:

- Pressure @16.5 psig for 10 minutes
- Vacuum to 22" Hg for 10 minutes
- Back to room pressure
- Vacuum to 22" Hg for 10 minutes
- No leakage
 - Pipe Deflected 5%
 - Pressure @ 10.8 psig for 10 minutes
 - No leakage

A 4" INSERTA TEE was installed into an 8" smooth wall PVC pipe with the following results:

- Pressure @ 28 psig for 5 minutes
- No leakage

INSERTA TEEs were installed into smooth wall PVC and concrete pipe with the following results:

- Pressure @ 13 psig for 10 minutes
- No leakage

INDEPENDENT TESTING BY MAJOR PIPE MANUFACTURERS

REFERENCE DOCUMENT: ASTM D3212

A 4" INSERTA TEE was installed into a 10" profile pipe with the following results:

- Pressure @ 12 psig for 50 hours
- No leakage

A 6" INSERTA TEE was installed into a 12" profile pipe with the following results:

- Pressure @ 12 psig for 24 hours
- No leakage

A 4" INSERTA TEE installed in 6"-12" solid wall PVC, a 6" INSERTA TEE installed in 8"-12" solid wall PVC and an 8" INSERTA TEE installed in 10"-12" solid wall PVC with the following results:

- Pressure @ 10.8 psig for 10 minutes
- No leakage

INSERTA TEEs (4", 6" and 8") installed in SaniTite HP pipe with the following results:

- Pressure @ 10.8 psig for 10 minutes
- No leakage

**This is highlighted testing on common sizes. Testing on additional size combinations available on request.*

INSERTA TEE® PRODUCT SPECIFICATION

SCOPE

This specification describes 2- through 30-inch (51 to 750 mm) INSERTA TEE service connections for use in gravity-flow sewer and drainage applications.

PRODUCT REQUIREMENTS

INSERTA TEE service connections shall consist of a PVC hub, rubber sleeve and stainless steel band. Connection shall be a compression fit into the cored wall of a mainline pipe. Hub shall be made from heavy-duty PVC material. Stainless steel clamping assembly shall be made from minimum 301 grade steel. Rubber sleeve and gasket, when applicable, shall meet the requirements of ASTM F477. Gaskets shall be installed by the manufacturer. The water-based solution provided by the manufacturer shall be used during assembly. *Do not use pipe lube.*

The INSERTA TEE can be installed into any mainline pipe or structure. Connection hubs are available to connect to: corrugated polyethylene, corrugated polypropylene, PVC C900, SDR 26 HWS, SDR 35 (gasketed bell, SWR spigot & solvent weld bell), IPS/Sch 40 (gasketed bell & solvent weld bell) and corrugated PVC. Custom pipe types available.

JOINT PERFORMANCE


INSERTA TEE product includes a watertight bell connection meeting the requirements of ASTM D3212.

FIELD PIPE AND JOINT PERFORMANCE

To assure watertightness, field performance verification may be accomplished by testing in accordance with ASTM F2487, ASTM C969 or ASTM F1417*. Appropriate safety precautions must be used when field-testing any pipe material. Contact the manufacturer for recommended leakage rates.

INSTALLATION

Installation shall be in accordance with manufacturer's recommended installation guidelines. The use of installation methods or hole saws not purchased from Inserta Fittings will void the performance warranty of the product. Backfill around the INSERTA TEE service connection shall be of the same material type and compaction level as specified for the mainline pipe installation. Contact your local representative or visit the website at www.insertatee.com for a copy of the latest installation guidelines.



Product configuration & availability subject to change without notice. Product detail may differ slightly from actual product appearance.

The Fatboy design creates a 360° stop around the fitting to prevent protrusion into the mainline.

Available in 4" and 6" SDR35, SDR28, SDR26 and IPS Sch40 products only

Visit our website at www.InsertaTee.com for specifications(CAD or PDF), application details and our installation video.

*Contact your local sales representative for acceptable watertight applications. Not all applications are standard and some may require additional technical assistance.


ADS "Terms and Conditions of Sale" are available on the ADS website, www.ads-pipe.com
The ADS logo and the Green Stripe are registered trademarks of Advanced Drainage Systems, Inc. INSERTA TEE® is a registered trademark Inserta Fittings Co. N-12®, N-12® HP and SaniTite® HP are registered trademarks of Advanced Drainage Systems, Inc. StormTech® is a registered trademark of StormTech, Inc. Hi-Q® and Sure-Lok® are registered trademarks of Hancor, Inc. Truss®, A2000® and DuroMaxx® are registered trademarks of Contech®. GOLDFLO® is a registered trademark of Prinsco, Inc. Ultra Corr™ and Ultra Rib™ are registered trademarks of JM Eagle™. Kor-Flo™ is a registered trademark of Royal Group®, Permalok® is a registered trademark of Permalok Corporation. Pro-21® is a registered trademark of Diamond Plastics Corporation®, Vylon® is registered trademark of Prime Conduit®, Weholite® is a registered trademark of KWH Pipe. Solflo® Max is a registered trademark of Soleno.

© 2018 Advanced Drainage Systems, Inc. #10790 07/18 MH



STRATEGIC SHIPPING LOCATIONS

The strategic location of our manufacturing facilities in Buford, Georgia, Forest Grove, Oregon and Findlay, Ohio make for fast arrival just about anywhere in North America. In fact, once you've worked with our products and experienced our service, we're confident you'll be impressed.



Advanced Drainage Systems, Inc.
4640 Trueman Blvd. Hilliard, OH 43026

1-800-821-6710

www.ads-pipe.com

THE MOST **ADVANCED** NAME IN WATER MANAGEMENT SOLUTIONS™

