>> Expansion Tank Support Kits Installation Instructions

For use with thermal expansion tanks up to 13" diameter. Follow local code requirements when installing this product.

Support kits are provided with one or two galvanized brackets and stainless steel snap-lock bands and may be fastened to stud wall. Optional installation to suspend with 3/8" threaded rod with double-nuts from top plate connector or Sioux Chief Sammy® screw is acceptable. Hardware and threaded rod for suspended installation must be purchased separately.

Wall Installation

Secure bracket with two #6 x 2" screws (provided) to wall making sure screws penetrate through wood or metal stud. Thread end of band through bracket and around body of thermal expansion tank. Secure band tightly around tank using screwdriver or 5/16" nut driver.

One or two bands can be installed. Follow local code requirements. When installing one band, make sure band is centered on tank. When installing two bands, evenly space the bands on expansion tank's upper and lower vertical 1/3 dimension. Excess band length may be trimmed if desired.

Suspended Installation

Note: Top Plate Connector or vertical Sammy® screw, 3/8" nuts and 3/8" threaded rod must be purchased separately.

Secure top plate connector or Sammy[®] screw to ceiling joist, rafter or beam using approved hardware. Cut threaded rod to desired length. Install first 3/8" nut on rod. Install galvanized bracket on rod and secure bracket with second 3/8" nut. Tighten both nuts to securely lock bracket in place. Second nut should be flush with end of threaded rod. Thread stainless steel band through bracket and secure band around thermal expansion tank and tighten with screwdriver or 5/16" nut driver. Excess band may be trimmed if desired.

ITEM NO.	
598-0210	Bulk, No-Break box of 10 Bands, Brackets and Hardware, Max Diameter 10"
598-0210PK1	Single Band Kit, Max Diameter 10", 1 kit/bag
598-0210PK2	Double Band Kit, Max Diameter 10", 1 kit/bag
598-0213	Bulk, No-Break Box of 10 Bands, Brackets and Hardware, Max Diameter 13"
550-2112	Single Band Kit, Max Diameter 13", 1 kit/bag
550-2113	Double Band Kit, Max Diameter 13", 1 kit/bag



Single Band Installation



Double Band Installation



Suspended Installation

A WARNING: Cancer and Reproductive Harm

www.P65Warnings.ca.gov

Packaged in the USA from domestic and foreign parts. #IS-598-02 Expansion Tank Support Kit Instruction Sheet – 9/18