Installation Instructions



Measure outside diameters of the two pipes to be joined, ensuring diameters fall within pipe size chart (see reverse side). Make sure the MAXADAPTOR[®] Coupling and pipes are devoid of dirt and debris. Before installing, tighten both sides of the MAXADAPTOR[®] Coupling, alternating back and forth, until coupling ID's are closely matched to the two pipe OD's. Lubricate pipe ends and gasket with soapy water solution.



Install pipe ends into coupling, just short of center pipe stop. The center section of the nylon securing cage has to be unimpeded in order for centrical reduction to take place. Ensure gasket is centered and properly engaged inside nylon securing cage (see insert) before tightening tension clamps.



Take up all slack in coupling with a cordless drill. Complete the installation by tightening the tension clamps with a pre-calibrated torque wrench, alternating back and forth, to 80 in/lbs. minimum.

Gripper Gasket LLC 1660 Leeson Lane Corona, CA 92879 (951) 479-4999		
grippergasket.com	Page 1	REV. 11/22



Installation Instructions

MAXADAPTOR[®] Couplings

Shielded, universal, high performance sewer repair couplings designed for the repair of most types and sizes of sewer/drainage pipes.



MAX Series

4" 12" 18" **PIPE MATERIAL** 5" 6" 8" 10" 14" 15" 16" Clav **Mission Clay** 6.65 7.68 9.90 18.30 22.30 5.37 12.43 14.46 **Building Products Clay** 5.20 7.75 12.40 14.40 18.25 22.25 9.80 Eastern Standard Clay 5.23 6.31 7.44 9.84 11.99 14.36 18.20 21.93 Gladding/McBean Clay 5.36 7.82 14.52 21.47 9.99 12.47 18.03 **Pacific Clay** 5.36 7.93 9.93 12.88 15.30 18.60 22.40 Metal No Hub Cast Iron 4.38 5.30 6.30 8.38 10.56 12.50 15.83 Service Weight Cast Iron 4.30 5.30 6.30 8.38 10.50 12.50 15.88 Extra Heavy Cast Iron 4.50 5.50 6.50 8.62 10.75 12.75 15.88 Ductile Iron 4.80 6.90 9.05 11.10 13.20 15.30 17.40 19.50 Steel 4.50 5.56 6.62 10.75 12.75 14.00 16.00 18.00 8.62 Copper 4.13 5.13 6.13 8.13 10.13 Stainless Steel 4.00 5.00 6.00 8.00 10.00 **Duriron**[®] 4.75 6.69 9.00 11.25 13.25 16.75 Plastic Schedule 40 Plastic 4.50 5.56 6.62 8.62 10.75 12.75 14.00 16.00 18.00 Thinwall Plastic PVC 4.21 6.27 8.16 10.20 12.24 (ASTM 3033) - SDR 26 Thinwall Plastic PVC 4.21 6.27 8.40 10.50 12.50 15.30 18.70 (ASTM 3034) - SDR 35 Thinwall Plastic ABS 10.50 12.50 4.21 5.30 6.27 8.40 (ASTM 2751) Miscellaneous Armco Truss 14.10 9.40 11.80 **Bituminous Fiber/** Min. Min. Min. Min. Min. Min. Orangeberg 4.64 5.82 6.92 9.14 11.24 13.44 Asbestos Cement 4.81 5.90 6.92 9.02 11.12 13.22 15.30 16.34 17.38 Class 1500 - Transite Min. Min. Min. Min. Min. Min. Min. Min. Concrete 5.50 6.50 7.50 10.00 12.45 14.50 19.60 22.50

U.S. Patent Nos. US 8,651,532 B2 & US 8,635,747 B2

Gripper Gasket LLC 1660 Leeson Lane Corona, CA 92879 (951) 479-4999		
grippergasket.com	Page 2	REV. 11/22

