SAMSUNG

SUBMITTAL AM072FXVAFH2AA

Page 1 of 2

Samsung DVM S Series, Heat Pump Condensing Unit

Job Name	Location			
Purchaser	Engineer			
Submitted to	Reference	Approval	Construction	
Unit Designation	Schedule #			

Purchaser				En
Submitted to)			Re
Unit Designa	ation			Sc
		System Specifications		
	US Ton (nominal)		6	
	Capacity (Btu/h)	Nominal / Rated Cooling ¹	72,000 / 69,000	
		Nominal / Rated Heating ¹	81,000 / 77,000	
Performance	Compressor Modulation Down to (Btu/h)		7,513	
	EER	Ducted / Non-Ducted	11.00 / 11.00	
	IEER	Ducted / Non-Ducted	20.20 / 24.20	
	High Heat COP	Ducted / Non-Ducted	3.30 / 3.30	
	Voltage	(ø/V/Hz)	3 / 208-230 / 60	
Power	Maximum Circuit Breaker (MCCB/ELB/ELCB)		35	
rowei	Minimum Circuit Am	Minimum Circuit Ampacity (MCA)		
	SCCR	kA	5	
la da a a l la ida	Total Capacity (%)		50 - 130% Of Outdoor Unit Cap	acity
Indoor Units	Maximum Indoor Unit Quantity		12	
0	Туре		SSC Scroll X 1	
Compressor	RLA (A)		14.3	
Refrigerant	R410A Factory Charge (lbs.) 12.		12.13	
Pipe Connections	Liquid X Suction (inc	ches)	3/8 X 3/4	
	Max. Distance - OD	U to IDU (feet)	656 (722 equivalent)	
Installation Limitation ²	Vertical Separation	ODU to IDU ³	361	
	(feet)	Highest/Lowest IDU	164	
	Total Refrigerant Pipe (feet)		3,280	
	Fon	Туре	Propeller X 1	
	Fan	Output (CFM)	7,240	
Candonaar Fan	Motor	Туре	DC	
Condenser Fan		Output (W)	630 X 1	
		FLA (A)	4	

	Motor	Output (W)	630 X 1
		FLA (A)	4
	Max. External Stat	ic Pressure ("WC)	0.31
	WXHXD	Inches	34 5/8 X 66 3/4 X 30 1/8
Dimensions	Weight	lbs.	405.7
	Shipping Weight	lbs.	440.9
Sound Level	dB (A)	Max.	60
Operating	Cooling	°F	23 - 120 (-13 - 120 with LACH guards ⁴)
Temperatures	Heating	°F	-13 - 75
Safety Certifications		ETL (UL 1995)	

	Intelligent logic to ensure proper operation within unit design limitations and operational parameters.
	High pressure sensor, low pressure sensor, over-voltage protection, compressor over- current protection, current transformer, fan motor voltage protection, fan motor thermal protection, overheat protection, phase detection protection, high voltage fuses
	Inverter PCB cooling done with liquid refrigerant to maintain optimal and safe operating temperatures.
Accessories	

Qty.	Model Number	Description
	WHG-T1	Top wind/hail guard (6 ton outdoor units)
	WHG-SL	Left side wind/hail guard (6 - 16 ton outdoor units)
	WHG-SR	Right side wind/hail guard (6 - 16 ton outdoor units)
	WHG-R1	Rear wind/hail guard (6 ton outdoor units)
	LACH-1-KIT	Low ambient cooling hood and side guards (6 ton outdoor units)
	LACH-1-SIDE KIT	Low ambient cooling side guards (6 ton outdoor units)
	MCM-C200	Heat pump mode selector switch
	MIM-B14	External contact control interface module (operation and error output, night silent mode manual activation)

Certified in accordance with the AHRI Variable Refrigerant Flow Multi-Split Air-Conditioners and Heat Pump (VRF) Certification Program which is based on the latest edition of AHRI Standard 1230.

When operating in cooling mode between -13°F and 5°F OA, LACH-1-KIT is required. When operating in cooling mode between 5°F and 23°F OA, LACH-1-SIDE KIT is required. Refer to technical bulletin at www.DVMdownload.com for full details and requirements.



Compatibility

Only compatible with Samsung DVM S indoor units (AM****N**CH**), AHU kits (MXD-K***AN), and UCK (MCM-D211UN).

Construction

The unit shall be galvanized steel with a baked on powder coated finish.

The heat exchanger shall be mechanically bonded fin to copper tube.

The aluminum fins of the heat exchanger shall have a protective coating.

Salt spray test method: ASTM B117-18 - the heat exchanger showed no unusual rust or corrosion development to 2,280 hours.

Controls

The unit shall be operated via NASA Protocol with controls provided by Samsung

The outdoor unit shall have a removable EEPROM that stores unit serial number, startup information, system settings, system tag/name, and other information.

Controls shall integrate with a BMS system without additional interface modules

Refrigerant System

The compressors shall be Samsung hermetically sealed, inverter driven, direct flash injected, DC scroll type with soft-start capability.

Flash injected compressors provide advanced low ambient heating performance.

Refrigerant flow shall be controlled by EEV (electronic expansion valve) throughout the system.

Subcooling devices in system maintain capacity at extreme system refrigerant pipe lengths and minimize refrigerant noise.

Other Features

Asymmetrical scroll design with rotating compressor operation/priority (where applicable).

Advanced oil recovery cycle logic (maximum duration in cool mode: 3 minutes, maximum duration in heat mode: 6 minutes, defrost cycles lasting over 3 minutes are considered oil recovery cycles). Oil recovery operation shall not interrupt heating or cooling operation.

Optional night quiet modes to reduce outdoor unit sound (4 levels) with automatic activation or manual activation (with MIM-B14).

Advanced intelligent defrost logic to significantly reduce defrost cycle frequency by monitoring air resistance across the condenser coil during heating operation to determine defrost operation initiation to prevent unnecessary defrost cycles.

Optional snow blowing logic to prevent snow accumulation on idle outdoor units

Continuous operation while outdoor unit(s) change between heating and cooling modes (conditions apply).

Maximum current control of outdoor unit(s) to limit current (50% - 100% of design current) adjustable at outdoor unit or central control devices: DMS 2 (MIM-D00AN), DMS 2.5 (MIM-D01AUN), BACnet Gateway (MIM-B17N, MIM-B17BUN), LON Gateway (MIM-B18N, MIM-B18BUN).

Energy savings options to reduce system energy consumption when average indoor room temperatures are greater than average indoor set temperatures in heating mode or when average indoor room temperatures are lower than average indoor set temperatures in cooling mode.

Samsung HVAC maintains a policy of ongoing development, specifications are subject to change without notice.








²Other pipe restrictions and requirements exist. Please consult technical data book or installation manuals for full details regarding limitations and other requirements for vertical separation over 163 feet (outdoor to lowest indoor).


³When outdoor unit is lower than indoor units, and vertical separation is greater than 131 feet, additional conditions apply. Please refer to supporting documents at www.SamsungHVAC.com


Samsung DVM S Series, Heat Pump Condensing Unit AM072FXVAFH2AA Dimensional Drawing











- 1) Gas refrigerant pipe opening
- (2) Liquid refrigerant pipe opening
- (3) Power conduit opening (2 X Ø1 3/4")
- (4) Communication conduit opening (2 X Ø1 3/8")
- (5) Power conduit opening (4 X Ø1 3/4")
- 6 Communication conduit opening (8 X Ø7/8")
- (7) Knock-out opening for refrigerant piping (7" X 3")
- 8 Anchor bolt hole (4 X Ø15/32")