



SUPCO IG403K

Universal Ignitor Kit Installation Data

Replaces: Robertshaw ignitors 41-403, 41-404, 41-407 & 41-409.

To replace these kits see the table below.

To Replace Part Number	Use These Parts
41 - 403	Two wire nuts
*41 - 404	Refer to instruction sheet. Attach two male pins, one "D" terminal connector, and one mounting bracket.
41 - 407	Attach two male pins and one "B" terminal connector.
41 - 409	Attach two male pins and one "D" terminal connector.

Parts View:




Wire Nut



Male Pins



Mounting Bracket
for 41-404



B Terminal Connector



D Terminal Connector

* **Note** - if needed cut off terminal connector, discard and use the two wire nuts to connect any ignitor.

Sealed Unit Parts Co., Inc.

2230 Landmark Place • Allenwood, NJ 08720 USA

Phone: 732-223-6644 • Fax: 732-223-1617

www.supco.com • info@supco.com

IG403K Cross Reference

OEM	OEM Part #	Robertshaw Part #	Exact	Functional
Carrier Corp	LH33ZS001A	41-409	X	
Carrier Corp	LH33ZS002	41-409	X	
Ducane	20015201	41-409	X	
Norton	201	41-403		X
Norton	271	41-403		X
Raypak	600915	41-403		X
Roberts Gordon	90434300	41-409		X
Snyder General	1380672	41-409	X	
Snyder General	1380680	41-409	X	
Snyder General	1380654	41-403		X
Trane Company	B138196P01	41-403		X
Trane Company	IGN26	41-409	X	
Trane Company	IGN26	41-403		X
Trane Company	IGN30	41-407	X	
Trane Company	IGN30	41-403		X
Weil McClain	511-330-139	41-409	X	
Weil McClain	511-330-193	41-403		X
Weil McClain	511-330-190	41-404	X	