AQUASPEC® FAUCETS

MODEL - Z81200 SERIES
4" [102] CENTERSET

TECHNICAL INFORMATION

FLOW: 2 GPM [7.6 L] PRESSURE COMPENSATING AERATOR *
MAXIMUM PRESSURE: 125 PSI
MAXIMUM TEMPERATURE: 180° F
HANDLE NUT TORQUE: 15-20 FT - LBS.
CARTRIDGE STYLE: QUARTER TURN CERAMIC DISK
(CAN USE ZURN METERING CARTRIDGE)

** OTHER AERATORS AVAILABLE BY REQUEST*

INSTALLATION INSTRUCTIONS

1. REMOVE FAUCET BODY FROM CARTON AND APPLY PLUMBERS PUTTY TO UNDERSIDE OF BODY.

2. PLACE FAUCET ON SINK AND REMOVE MOUNTING NUTS (ITEM #7A) FROM BAG G60502.

3. HAND TIGHTEN MOUNTING NUTS FROM UNDER SINK. MAKE SURE FAUCET IS CENTERED PROPERLY. **DO NOT OVER TIGHTEN**.

4. ATTACH LAVATORY SUPPLIES TO FAUCET WITH RISER NUTS (ITEM #7B).

5. OPTIONAL: POP-UP (-P)
   GRID STRAINER (-G)
   ADA OFFSET GRID DRAIN (-GH)

   INSTALL POP-UP OR GRID STRAINER IN SINK OUTLET AND PLUMB WASTE CONNECTION.

6. INSTALL SPOUT INTO BASE AND TIGHTEN NUT (SEE VIEWS FOR SWING/RIGID CONNECTION). REFER TO "140° SWING INSTALLATION INSTRUCTIONS" FOR RESTRICTED SWING CONNECTION.

7. TURN SUPPLY WATER ON AND OPERATE FAUCET CHECKING FOR LEAKS.

8. IT MAY BE NECESSARY TO SHUT WATER OFF AND REMOVE CARTRIDGES TO CLEAN SUPPLY LINES. CARTRIDGES CAN BE REMOVED BY FIRST REMOVING THE HANDLES. COLOR INDEXES CAN BE REMOVED BY INSERTING A PIN INTO THE HOLE ON THE UNDERSIDE OF THE HANDLE. AFTER THE HANDLES HAVE BEEN REMOVED, UNSCREW THE HANDLE NUTS AND PULL UP ON THE CARTRIDGE. ZURN WILL SUPPLY HANDLE PORT PLUGS (ZURN PART #61094001) AT YOUR REQUEST.

9. REPLACE CARTRIDGES IN BODY AND HAND TIGHTEN HANDLE NUTS. PLACE HANDLES ON THE CARTRIDGE STEM AND LOCATE THEM AS DESIRED. TIGHTEN HANDLE NUT TO 15-20 FT-LBS OF TORQUE.

10. REPLACE HANDLE SCREWS AND COLOR INDEX BUTTONS.

11. INSTALL AERATOR INTO FAUCET AND HAND TIGHTEN. IT MAY BE NECESSARY TO UNSCREW AND CLEAN AERATOR AT START-UP.

ZURN INDUSTRIES, LLC. ♦ COMMERCIAL BRASS OPERATION ♦ 5900 ELWIN BUCHANAN DRIVE ♦ SANFORD NC 27330
Phone: 1-800-997-3876 ♦ Fax: 919-775-3541 ♦ World Wide Web: www.zurn.com
In Canada: ZURN INDUSTRIES LIMITED ♦ 3544 Nashua Drive ♦ Mississauga, Ontario L4V1L2 ♦ Phone: 905-405-8272 Fax: 905-405-1292

Form # CF98 Date: 1/3/12
C.N. No. 128465 Rev. F

MAINTENANCE


1. YOUR ZURN AQUASPEC FAUCET HAS A HIGHLY POLISHED NICKEL CHROME PLATED FINISH. CLEAN WITH SOAP AND WATER OR A MILD CLEANER WHICH IS SAFE FOR CHROME PLATING. DO NOT USE ACIDS OR TOILET BOWL CLEANER AS THEY WILL DAMAGE THE FINISH.

2. AQUASPEC FAUCETS CONTAIN CERAMIC DISK CARTRIDGES WHICH REQUIRE NO MAINTENANCE. TO REMOVE THE CARTRIDGE, SHUT THE WATER OFF, LOOSEN THE HANDLE NUTS AND PULL UP ON THE CARTRIDGE.

REPLACEMENT PARTS

COLD WATER CARTRIDGE	59517001
HOT WATER CARTRIDGE	59517002
INDEX BUTTONS	G60500

Z812A1 PICTURED




Z81200 PARTS LIST

ITEM			QTY	ITEM			QTY
1	59440001	HANDLE NUT	2	7	G60502	MOUNTING & COUPLING NUTS BAG	1
2	59517001	SHORT COLD CARTRIDGE	1	7A	59530002	MOUNTING NUT	2
3	59517002	SHORT HOT CARTRIDGE	1	7B	59532001	1/2" [13mm] NPSM RISER NUT	2
4	58155019	O-RING	1				
5	60467001	BASE	1				
6	60454001	BODY	1				

Form # CF98 Date: 1/3/12
C.N. No. 128465 Rev. F

4” CENTERSET GOOSENECK

Z812U4 Parts List



Item	Part Number	Description	Qty
1	G60550	6” Tubular ‘U’ Spout	1
1A	61401002	‘U’ Spout S/A	1
1B	58155018	O-Ring	2
1C	59666001	Plastic Split Washer	2
1D	59436001	Spacer Washer	1
2	G60525	Aerator Assembly	1
2A	58155015	O-Ring	1
2B	60524001	Aerator Adaptor	1
2C	59556001	3/4”-27 Female Aerator - 2.2 GPM	1
3	G60504	Vandal-Resistant Metal Blade Handles	1
3A	G60500	Hot/Cold Color-Coded Indexes	1
	59454001	Hot Index	1
	59454002	Cold Index	1

Item	Part Number	Description	Qty
3B	62464001	10-32 Screw	2
3C	59453001	4” Wrist Blade Handle	2
4	59440001	Handle Nut	2
5	59517001	Short Cold Cartridge	1
6	59517002	Short Hot Cartridge	1
7	60467001	Base	1
8	58155019	O-Ring	1
9	60454001	4” Centerset Gooseneck Body	1
10	G60502	Mounting Hardware	1
10A	59530002	Mounting Nut	2
10B	59532001	1/2" NPSM Riser Nut	2

ZURN INDUSTRIES, INC. ♦ COMMERCIAL BRASS OPERATION ♦ 2640 SOUTH WORK STREET ♦ FALCONER NY 14733
Phone: 1-716-665-1132 ♦ Fax: 1-716-665-1135 ♦ World Wide Web: www.zurn.com
In Canada: ZURN INDUSTRIES LIMITED ♦ 3544 Nashua Drive ♦ Mississauga, Ontario L4V1L2 ♦ Phone: 905/405-8272 Fax: 905/405-1292

AquaSpec® is a registered trademark of Zurn Industries, Inc.
©2007 Zurn Industries, Inc.

Rev. B Date: 2/9/07 C.N. No. 105757
Form No. CF587 Product No. Z812U4