

# Hot Box® Fiberglass

## BACKFLOW PREVENTION ASSEMBLY ENCLOSURE SPECIFICATION

### GENERAL

#### 1.1 WORK INCLUDED

- A. Provide and install manufactured backflow prevention assembly enclosure.

#### 1.2 QUALITY ASSURANCE

- A. Qualifications: The backflow prevention assembly enclosure manufacturer shall be a company specializing in the manufacture of backflow prevention assembly enclosures with at least 29 years of successful experience designing and selling enclosures to various customers in different climatic regions.

#### 1.3 STORAGE AND HANDLING

- A. Store products in shipping containers and maintain in dry place until installation.

#### 1.4 ACCEPTABLE MANUFACTURERS

- A. **Hot Box®** or Engineer approved equal.

#### 1.5 REFERENCES

- A. ASTM B209.
- B. ASTM B221.
- C. ASSE 1060-Performance Requirements for Outdoor Enclosures for Backflow Prevention assemblies.

### PRODUCTS

#### 2.1 FIBERGLASS ENCLOSURES

- A. Available in Drop over, Flip top, Vent Guard, Valve Cover & Roks.
- B. All fiberglass enclosures are lockable.
- C. Anchoring is supplied to secure to the concrete pad.
- D. Drain ports are sized for full port backflow discharge and are designed for a one way operation allowing backflow discharge but not allowing wind, debris and small animals to enter the enclosure.
- E. Standard enclosures shall be designed to support a minimum vertical load of 100lb/sf.
- F. Standard enclosures shall be designed to support wind speeds up to 120mph.
- G. Standard enclosures are ASSE 1060 certified.

#### 2.2 MATERIALS OF FABRICATION

- A. Fiberglass is minimum of 1/8" thick Thixotropic polyester resin reinforced with fiberglass strand. A smooth yacht quality finish, protected with UV inhibited isophthalic polyester gel coat.
- B. Non molded products will utilize an Industrial exterior texture.
- C. No wood or particle board used in the construction of any Hot Box product.
- D. Insulation shall be 1"-1.5" unicellular, non-wicking, polyisocyanate foam frothed or sprayed in place.
- E. The Insulation shall have the following properties:

R-Value	8
Dimensional Stability	less than 2% linear change
Compressive Strength	51psi
Flame point	325 degrees

Hot Box  
3621 Industrial Park Drive  
Lenoir City, TN 37771

Contact Information  
Phone: (800) 736-0238  
hotboxsales@hubbell.com  
www.hot-box.com

Water absorption  
Porosity

.037psf  
91%

### **3.1 HEATING EQUIPMENT (ASSE 1060 Class I-Required; ASSE 1060 Class II-Optional)**

- A. Heating equipment will protect the piping and equipment from exterior temperatures to -30°F. ETL listed thermostatically controlled wall mounted air forced heaters or UL listed self regulating cable(s) shall be furnished and designed by the manufacturer of the enclosure to maintain the equipment at +40°F, In accordance with ASSE 1060 1.2.2.1.
- B. Heating equipment shall be wall mounted to the supplied heater plates and a minimum 8" above the slab unless it is UL or ETL certified and NEC approved for submersion.
- C. Power source shall be protected with a GFI receptacle, U.L. 943, NEMA.3R. Mounted a minimum of 8" from the bottom of the receptacle to the top of the slab.
- D. Separate 20 amp circuits are recommended for each heater, so in the event a circuit fails all other circuits will remain powered. Installations must be in accordance with the local and national codes.
- E. The heaters shall be ETL listed for wet/damp locations.

### **4.1 RECOMMENDED SLAB SIZE & INSTALLATION**

- A. The recommended slab size shall be 9" larger than the enclosures exterior dimensions and a minimum of 4" thick.
- B. The enclosure shall be assembled per the manufactures instructions provided with the enclosure.

Hot Box  
3621 Industrial Park Drive  
Lenoir City, TN 37771

Contact Information  
Phone: (800) 736-0238  
hotboxsales@hubbell.com  
www.hot-box.com