



WHITE-RODGERS

S81/S84 Series Transformers

GENERAL PRECAUTIONARY INFORMATION

WARNING

To prevent electrical shock and/or equipment damage, disconnect electric power to system at main fuse or circuit breaker box until installation is complete.

CAUTION

Do not use on circuits exceeding rating of transformer. Higher voltage will damage control and could cause personal injury or property damage.

NOTES

If power disconnect switch is not in sight, lock it in the open position and tag it to prevent unexpected application of power.

All wiring must conform to local and national electrical codes and ordinances.

All wiring should be performed by a qualified electrician.

The wiring to and from the transformer must be of proper gauge and type as required by code.



WHITE-RODGERS DIVISION
EMERSON ELECTRIC CO.
9797 REAVIS ROAD
ST. LOUIS, MISSOURI 63123-5398

Printed in U.S.A.

PART NO. 37-5605A

9544



WHITE-RODGERS

S81/S84 Series Transformers

GENERAL PRECAUTIONARY INFORMATION

WARNING

To prevent electrical shock and/or equipment damage, disconnect electric power to system at main fuse or circuit breaker box until installation is complete.

CAUTION

Do not use on circuits exceeding rating of transformer. Higher voltage will damage control and could cause personal injury or property damage.

NOTES

If power disconnect switch is not in sight, lock it in the open position and tag it to prevent unexpected application of power.

All wiring must conform to local and national electrical codes and ordinances.

All wiring should be performed by a qualified electrician.

The wiring to and from the transformer must be of proper gauge and type as required by code.



WHITE-RODGERS DIVISION
EMERSON ELECTRIC CO.
9797 REAVIS ROAD
ST. LOUIS, MISSOURI 63123-5398

Printed in U.S.A.

PART NO. 37-5605A

9544